

INSPECTION HISTORY REPORT
Wednesday, April 21, 2021

APPLICATION	PROPERTY ADDRESS/PERMIT	INSPECTION	RESULT DATE/STATUS	INSPECTOR
19 00000470	6836 CAMBRIDGE DR 37 00 POOL, BELOW/INGROUND 37 00 POOL, BELOW/INGROUND	6080 0002 POOL PRE-PLASTER 6090 0001 POOL FINAL RES COMM: provide final grade & drainage survey.	4/21/21 APPROVED 4/21/21 DISAPPROVED	TC TC
19 00002675	6520 BROWNING DR 12 00 BLDG, COMMERCIAL-NEW	1017 0002 BLDG FIRE WALLS/ASSEMBLIE RES COMM: 1st floor shearwall units only. Clean up trash	4/21/21 APPROVED	DJH
20 00003375	6901 DAVIS BLVD 12 00 BLDG, COMMERCIAL-NEW	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: Need fire dept inspection. Need to apply for C.O. No water RES COMM: Sink drain line flex line does not meet code.	4/21/21 DISAPPROVED	DJH
20 00004645	7364 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION RES COMM: Corrections not made. Repair erosion control and remove RES COMM: prot a john out of street.	4/21/21 APPROVED WITH EXCEPT	MP
20 00004876	7617 IRA DR 10 00 BLDG, SF-NEW	1050 0002 BLDG SITE CONCRETE WORK RES COMM: Corrections not made from previous tag, see previous tag. RES COMM: Worker on site still working not ready.	4/21/21 DISAPPROVED	MP
20 00004890	7208 SMITH FARM DR 10 00 BLDG, SF-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA	4/21/21 APPROVED	MP
20 00004944	7245 SMITH FARM DR 10 00 BLDG, SF-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA	4/21/21 APPROVED	MP
20 00005072	6313 ROVER LN 10 00 BLDG, SF-NEW	1090 0003 BLDG FINAL-BUILDING DEPT	4/21/21 APPROVED	MP
21 00000100	8013 ODELL ST 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1046 0002 BLDG TEMPORARY ELEC RELEA 1047 0002 BLDG TEMPORARY GAS RELEAS	4/21/21 APPROVED 4/21/21 APPROVED	TC TC
21 00000109	6445 IRON HORSE BLVD 10A 00 BLDG, SF-TOWNHOME NEW	1050 0001 BLDG SITE CONCRETE WORK	4/21/21 APPROVED	MP
21 00000110	6441 IRON HORSE BLVD 10A 00 BLDG, SF-TOWNHOME NEW	1050 0001 BLDG SITE CONCRETE WORK	4/21/21 APPROVED	MP
21 00000111	6437 IRON HORSE BLVD 10 00 BLDG, SF-NEW	1050 0001 BLDG SITE CONCRETE WORK	4/21/21 APPROVED	MP
21 00000112	6433 IRON HORSE BLVD 10A 00 BLDG, SF-TOWNHOME NEW	1050 0001 BLDG SITE CONCRETE WORK	4/21/21 APPROVED	MP
21 00000113	6429 IRON HORSE BLVD 10A 00 BLDG, SF-TOWNHOME NEW	1050 0001 BLDG SITE CONCRETE WORK	4/21/21 APPROVED	MP
21 00000114	6425 IRON HORSE BLVD 10A 00 BLDG, SF-TOWNHOME NEW	1050 0001 BLDG SITE CONCRETE WORK	4/21/21 APPROVED	MP
21 00000522	6620 BROOKSHIRE TR 14 00 BLDG, SF FOUNDATION	1037 0002 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/21/21 APPROVED	TC
21 00000634	7340 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1046 0002 BLDG TEMPORARY ELEC RELEA	4/21/21 APPROVED	MP
21 00001101	8309 SANDY CT 37 00 POOL, BELOW/INGROUND	6080 0001 POOL PRE-PLASTER	4/21/21 APPROVED	TC
21 00001170	5036 RUFÉ SNOW DR 12 00 BLDG, COMMERCIAL-NEW	1014 0001 BLDG ELEC ROUGH-BURY/WALL RES COMM: U.E. SLAB ONLY.	4/21/21 APPROVED	DJH
21 00001260	8704 WOODBURY CT 10 00 BLDG, SF-NEW	1001 0002 BLDG STRUCTURAL CONCRETE RES COMM: Place address on the lot. Pick up trash in the back yard RES COMM: and open lot.	4/21/21 APPROVED WITH EXCEPT	DJH
21 00001853	8625 DAVIS BLVD 37 00 POOL, BELOW/INGROUND	6010 0001 POOL STAKE OUT	4/21/21 APPROVED	DJH
21 00002048	8520 FRESH MEADOWS RD 10 00 BLDG, SF-NEW	1000 0003 BLDG ROUGH PLUMBING/GAS T RES COMM: Need port a john on site. Clean the street and concrete RES COMM: clean out area and gutter. Water test head is too low same RES COMM: as the last inspection- fees due.	4/21/21 DISAPPROVED WITH PEN	DJH

21 00002193	7517 REGAL LN 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Missing cutoff. backfill meter.	4/21/21 APPROVED WITH EXCEPT	MP
21 00002483	7709 SILVERLEAF DR 83 00 MECH, RES-WHOLE SYS. REPLACE	4090 0001 MECH MECHANICAL FINAL	4/21/21 APPROVED	GT
21 00002556	7317 CROSS KEYS CIR 14 00 BLDG, SF FOUNDATION	1037 0002 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/21/21 APPROVED	TC
21 00002696	6745 CYLINDA SUE CIR 28S 00 ELEC, PHOTOVOLTAIC (SOLAR)	2015 0001 ELEC SERVICE UPGRADE	4/21/21 APPROVED	TC
21 00002704	7837 EMERALD HILLS WY 35 00 PLBG, MISCELLANEOUS	3090 0002 PLBG PLUMBING FINAL	4/21/21 APPROVED	MP
21 00002761	7705 CHASEWOOD DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/21/21 APPROVED	TC
21 00002805	5416 ROBERTA DR 35 00 PLBG, MISCELLANEOUS 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL RES COMM: cant see where the pan drains or if it has a shutoff. 3090 0002 PLBG PLUMBING FINAL RES COMM: WH can't drain to the floor must drain to the exterior or RES COMM: have a shutoff	4/21/21 DISAPPROVED 4/21/21 DISAPPROVED	GT GT
21 00002871	6929 GLENHURST DR 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/21/21 APPROVED	TC
21 00002893	7120 CHELSEA DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/21/21 APPROVED	GT
21 00002935	7800 MOCKINGBIRD LN 01B 00 C OF O-CHANGE NAME/OWNER/REMOD	1095 0001 BLDG CERTIFICATE OF OCCY	4/21/21 APPROVED	DJH
21 00002958	8609 SUMMER TREE LN 84 00 MECH, RES-OUTDOOR AC/HT PUMP	4090 0001 MECH MECHANICAL FINAL	4/21/21 APPROVED	GT
21 00002971	9005 TRAILS EDGE DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/21/21 APPROVED	GT
21 00002991	7821 DOUGLAS LN 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/21/21 APPROVED	TC
21 00002992	7437 S SANDHURST LN 24 00 ELEC, SERVICE CHANGE/ADD	2090 0001 ELEC FINAL	4/21/21 APPROVED	TC
21 00003005	8017 GLENVIEW DR H 01C 00 C OF O-NEW OCCUPANT/NEW USE 01C 00 C OF O-NEW OCCUPANT/NEW USE	1046 0001 BLDG TEMPORARY ELEC RELEA RES COMM: NO ACCESS, DOOR IS LOCKED. 1046 0002 BLDG TEMPORARY ELEC RELEA RES COMM: Loose wires is bathroom and water heater closet, remove RES COMM: cord in ceiling at water heater closet.	4/21/21 DISAPPROVED 4/21/21 APPROVED WITH EXCEPT	DJH DJH
21 00003018	3621 DAWN DR 24 00 ELEC, SERVICE CHANGE/ADD	2090 0001 ELEC FINAL	4/21/21 APPROVED	GT

INSPECTION HISTORY REPORT
Tuesday, April 20, 2021

APPLICATION	PROPERTY ADDRESS/PERMIT	INSPECTION	RESULT DATE/STATUS	INSPECTOR
20 00001815	8001 NORTHEAST PKWY 12 00 BLDG, COMMERCIAL-NEW	1017 0005 BLDG FIRE WALLS/ASSEMBLIE RES COMM: Seal wall patch and floor section C, framing OK.	4/20/21 APPROVED WITH EXCEPT	DJH
20 00002957	7628 REGAL LN 10 00 BLDG, SF-NEW	1090 0002 BLDG FINAL-BUILDING DEPT	4/20/21 APPROVED	MP
20 00004351	8305 SOUTHRIDGE CT 37 00 POOL, BELOW/INGROUND	6090 0002 POOL FINAL	4/20/21 APPROVED	TC
20 00004876	7617 IRA DR 10 00 BLDG, SF-NEW	1050 0001 BLDG SITE CONCRETE WORK RES COMM: Radius over 30" max angles. Horizontal cuts not done. Water RES COMM: standing in approach. Max steel spacing on private side RES COMM: 24" o.c.e.w. max. No plans on site. Truck blocking approach RES COMM: Dowels into street must be 6" below cut of street, RES COMM: Inspections stop not ready	4/20/21 DISAPPROVED	MP
20 00005081	5505 TRAVELLER DR 10 00 BLDG, SF-NEW	1005 0002 BLDG EXTERIOR SHEATHING RES COMM: Sheathing only, firewall not ready	4/20/21 PARTIALLY APPROVED	MP
20 00005120	6828 MEADOW CREST DR 10 00 BLDG, SF-NEW	1050 0002 BLDG SITE CONCRETE WORK RES COMM: Sidewalks 6816-6832. Max spacing 18" o.c.e.w. Steps must RES COMM: meet code at final.	4/20/21 APPROVED WITH EXCEPT	MP
20 00005121	6832 MEADOW CREST DR 10 00 BLDG, SF-NEW	1050 0002 BLDG SITE CONCRETE WORK RES COMM: Sidewalks 6816-6832. Max spacing 18" o.c.e.w. Steps must RES COMM: meet code at final.	4/20/21 APPROVED WITH EXCEPT	MP
20 00005122	6820 MEADOW CREST DR 10 00 BLDG, SF-NEW	1050 0002 BLDG SITE CONCRETE WORK RES COMM: Sidewalks 6816-6832. Max spacing 18" o.c.e.w. Steps must RES COMM: meet code at final.	4/20/21 APPROVED WITH EXCEPT	MP
20 00005123	6824 MEADOW CREST DR 10 00 BLDG, SF-NEW	1050 0002 BLDG SITE CONCRETE WORK RES COMM: Sidewalks 6816-6832. Max spacing 18" o.c.e.w. Steps must RES COMM: meet code at final.	4/20/21 APPROVED WITH EXCEPT	MP
20 00005126	6816 MEADOW CREST DR 10 00 BLDG, SF-NEW	1050 0002 BLDG SITE CONCRETE WORK RES COMM: Sidewalks 6816-6832. Max spacing 18" o.c.e.w. Steps must RES COMM: meet code at final.	4/20/21 APPROVED WITH EXCEPT	MP
20 00005142	6805 MEADOW RD 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING RES COMM: BLOCK ALL SEAMS IN SHEATHING & NAIL. RES COMM: ADD NAILS OVER FRONT DOOR. RES COMM: SHEATHING INCOMPLETE ON PATIO AREA. RES COMM: NO PERMIT PACK FOUND ON JOB SITE.	4/20/21 DISAPPROVED	TC
20 00005192	5501 TRAVELLER DR 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING RES COMM: No plans on site, no inspections made.	4/20/21 DISAPPROVED	MP
20 00005463	8536 FRESH MEADOWS RD 10 00 BLDG, SF-NEW	1015 0004 BLDG SECONDS	4/20/21 APPROVED	DJH
21 00000100	8013 ODELL ST 10 00 BLDG, SF-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA RES COMM: NO TEMP POWER FORM. RES COMM: NO ACCESS TO UPPER ATTIC.	4/20/21 DISAPPROVED	TC
	10 00 BLDG, SF-NEW	1047 0001 BLDG TEMPORARY GAS RELEAS RES COMM: NO TEMP POWER FORM. RES COMM: NO ACCESS TO UPPER ATTIC.	4/20/21 DISAPPROVED	TC
21 00000114	6425 IRON HORSE BLVD 10A 00 BLDG, SF-TOWNHOME NEW	1047 0002 BLDG TEMPORARY GAS RELEAS	4/20/21 APPROVED	MP
21 00000350	7709 REIS LN 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING RES COMM: See engineering	4/20/21 APPROVED	MP
	10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: Main 1" water out of wall, not insulates, not secured. RES COMM: Damaged stud in garage by 3" pvc. Seal holes above garage RES COMM: door to exterior. Outlet must be 3" away from tub on 2nd RES COMM: floor. Support pvc every 4'. Parallel walls within 3' of RES COMM: property line must be 1hr fire rated walls to roof deck. RES COMM: Kitchen loop vent must be above flood rim of fixture. Sound RES COMM: proofing required within 150' of tracks. Gas and water test RES COMM: ok.	4/20/21 DISAPPROVED	MP
21 00000352	7713 REIS LN			

10	00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING	4/20/21 APPROVED	MP
10	00 BLDG, SF-NEW	RES COMM: See engineering 1015 0001 BLDG SECONDS	4/20/21 DISAPPROVED	MP
		RES COMM: Kitchen loop vent must be above flood rim of fixture. RES COMM: Support horizontal PVC every 4'. 1" pex out of wall, not RES COMM: secured every 32" not insulated. Master shower pan not RES COMM: level. Sound proof walls and windows required within 150' RES COMM: of tracks. Backfall on 2nd AC drain over bedroom. Secure RES COMM: pan and TP line in wall. Gas and water test ok.		
21 00000632	7384 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS	4/20/21 APPROVED	MP
21 00000747	6433 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1015 0003 BLDG SECONDS	4/20/21 APPROVED	MP
21 00000925	6909 BRAZOS BEND DR 37 00 POOL, BELOW/INGROUND	6090 0001 POOL FINAL RES COMM: PROVIDE FINAL GRADE & DRAINAGE SURVEY FOR POOL FINAL.	4/20/21 DISAPPROVED	TC
21 00000938	7509 REGAL LN 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T	4/20/21 APPROVED	MP
21 00000941	7521 REGAL LN 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T	4/20/21 APPROVED	MP
21 00001039	7336 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: See tag in file, walked house with Cooper.	4/20/21 DISAPPROVED	MP
21 00001060	6717 MEADOW RD 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING	4/20/21 APPROVED	TC
21 00001170	5036 RUFÉ SNOW DR 12 00 BLDG, COMMERCIAL-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Rough plumbing under the slab only. Provide form board RES COMM: survey at foundation inspection.	4/20/21 APPROVED	DJH
21 00001388	6241 SHERBERT DR 37 00 POOL, BELOW/INGROUND	6030 0002 POOL DECK STEEL & BONDING	4/20/21 APPROVED	DJH
21 00001397	7320 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T	4/20/21 APPROVED	MP
21 00001398	7344 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T	4/20/21 APPROVED	MP
21 00001400	8621 HIGHTOWER DR 37 00 POOL, BELOW/INGROUND	6030 0001 POOL DECK STEEL & BONDING	4/20/21 APPROVED	TC
21 00001467	6909 BRAZOS BEND DR 11 00 BLDG, SF/MINOR REMODEL 50SF+ 11 00 BLDG, SF/MINOR REMODEL 50SF+	1015 0001 BLDG SECONDS 1090 0001 BLDG FINAL-BUILDING DEPT	4/20/21 APPROVED 4/20/21 APPROVED	TC TC
21 00001473	7713 REIS LN 72R 00 FIRE SPRINKLER RESIDENTIAL SYS	5040 0001 FIRE SPRINKLER AIR/HYDRO	4/20/21 APPROVED	MP
21 00001474	7709 REIS LN 72R 00 FIRE SPRINKLER RESIDENTIAL SYS	5040 0001 FIRE SPRINKLER AIR/HYDRO	4/20/21 APPROVED	MP
21 00001537	7628 REGAL LN 45 00 FENCE-CHAIN/WOOD/OTHER	1502 0001 FENCE FINAL	4/20/21 APPROVED	MP
21 00001662	7612 REGAL LN 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: Beams holding water. Cap off open sewer vents. Ufer's not RES COMM: to code, must be in bottom 2" of beam to direct contact RES COMM: with earth (no plastic or cables.) Exposed PVS in bathroom.	4/20/21 DISAPPROVED	MP
21 00001663	7608 REGAL LN 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: Beams holding water. Cap off open sewer vents. Ufer's not RES COMM: to code, must be in bottom 2" of beam to direct contact RES COMM: with earth (no plastic or cables.) Exposed PVC in bathroom.	4/20/21 DISAPPROVED	MP
21 00001728	7621 JEAN ANN DR 28S 00 ELEC, PHOTOVOLTAIC (SOLAR)	2015 0002 ELEC SERVICE UPGRADE	4/20/21 APPROVED	TC
21 00001740	7212 CROSS KEYS CIR 37 00 POOL, BELOW/INGROUND	6025 0001 POOL UNDERGROUND ELECTRIC	4/20/21 APPROVED	TC
21 00001803	7628 REGAL LN 32R 00 PLBG, RESIDENTIAL IRRIGATION	3003 0001 PLBG LAWN IRRIGATION	4/20/21 APPROVED	MP
21 00001971	7232 SMITH FARM DR 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: Several areas seen where PVC lines are not properly RES COMM: sleeved. Chair cables off plbg. Cap off open sewer lines.	4/20/21 DISAPPROVED	MP
21 00002048	8520 FRESH MEADOWS RD			

	10 00 BLDG, SF-NEW	1000 0002 BLDG ROUGH PLUMBING/GAS T RES COMM: Water level too low. Need port a john on site.	4/20/21 DISAPPROVED	DJH
21 00002110	8709 MONTROSE DR 10 00 BLDG, SF-NEW	1001 0003 BLDG STRUCTURAL CONCRETE RES COMM: Chair all steel and cable as needed.	4/20/21 APPROVED WITH EXCEPT	DJH
21 00002123	5501 MISTY MEADOW 24 00 ELEC, SERVICE CHANGE/ADD	2090 0001 ELEC FINAL	4/20/21 APPROVED	GT
21 00002143	7520 TEAKWOOD CT 14 00 BLDG, SF FOUNDATION	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/20/21 APPROVED	TC
21 00002288	7589 REGAL LN 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Missing cut off on water service line.	4/20/21 APPROVED WITH EXCEPT	MP
21 00002314	7513 REGAL LN 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T	4/20/21 APPROVED	MP
21 00002487	4709 REDONDO ST 14 00 BLDG, SF FOUNDATION	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: Need engineer's final inspection report.	4/20/21 DISAPPROVED	DJH
21 00002613	6805 DREAM DUST DR 14 00 BLDG, SF FOUNDATION	1090 0001 BLDG FINAL-BUILDING DEPT	4/20/21 APPROVED	MP
21 00002671	4805 WOODCREEK CT 45 00 FENCE-CHAIN/WOOD/OTHER	1502 0001 FENCE FINAL	4/20/21 APPROVED	DJH
21 00002704	7837 EMERALD HILLS WY 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL RES COMM: Leak on 2" to kitchen. Cannot have washing machine trap RES COMM: below slab.	4/20/21 DISAPPROVED	MP
21 00002716	6964 SOUTHAMPTON DR 45 00 FENCE-CHAIN/WOOD/OTHER	1502 0001 FENCE FINAL	4/20/21 APPROVED	MP
21 00002827	6450 IRON HORSE BLVD 21C 00 ELEC, COMM/IND-NEW	2090 0001 ELEC FINAL	4/20/21 APPROVED	DJH
21 00002883	9001 BOULEVARD 26 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL RES COMM: Plumbing water supply lines replaced. Pex line support and RES COMM: secure 32" on center. Insulate pex line all the way to the RES COMM: fixture shut off.	4/20/21 DISAPPROVED	DJH
21 00002918	6537 WOODCREEK LN 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/20/21 APPROVED	GT
21 00002925	6876 HICKORY HOLLOW LN 14 00 BLDG, SF FOUNDATION	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/20/21 APPROVED	TC
21 00002942	7613 TERESA CT 35 00 PLBG, MISCELLANEOUS	3005 0002 PLBG PLUMBING ROUGH RES COMM: 2nd attempt out for inspections, no answer at door at 3pm. RES COMM: Tunnel hole full of water, no access provide for RES COMM: inspections. No permit, pictures found posted on site. No RES COMM: test on repair found. Exterior beam busted out requires RES COMM: engineers letter of repair and approval. Fee's due.	4/20/21 DISAPPROVED WITH PEN	MP
21 00002959	8304 VINE WOOD DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/20/21 APPROVED	GT
21 00002984	7832 A IRISH DR 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0002 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/20/21 APPROVED	TC
21 00002987	8608 BROOKRIDGE DR 01R 00 C OF O - SINGLE FA	MILY RENTAL 1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/20/21 APPROVED	TC
21 00002997	6733 DRIFFIELD CIR W 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/20/21 APPROVED	GT
21 00003007	8761 BRIDGE ST 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection RES COMM: add keyless locks on front,back,& garage doors. RES COMM: add door viewer on garage door.	4/20/21 DISAPPROVED	TC

INSPECTION HISTORY REPORT
Monday, April 19, 2021

APPLICATION	PROPERTY ADDRESS/PERMIT	INSPECTION	RESULT DATE/STATUS	INSPECTOR
17 00000929	9000 COURTENAY ST 17 00 BLDG, MF-NEW	1090 0003 BLDG FINAL-BUILDING DEPT REQ COMM: d RES COMM: MEPs units only 1st floor, punch list made.	4/19/21 DISAPPROVED	DJH
17 00005212	9001 GRAND AVE 17 00 BLDG, MF-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA RES COMM: Cut high weeds. Lock out main breaker.	4/19/21 APPROVED WITH EXCEPT	DJH
19 00002657	6490 IRON HORSE BLVD 12 00 BLDG, COMMERCIAL-NEW	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: Units only section A units only. punch list made.	4/19/21 DISAPPROVED	DJH
19 00003246	9153 BELSHIRE DR 130 12A 00 BLDG, COMMERCIAL-ADDITION/TFO	1018 0001 BLDG INSULATION	4/19/21 APPROVED	DJH
20 00001313	8611 DAVIS BLVD 15 00 BLDG, DUPLEX UNITS-NEW 15 00 BLDG, DUPLEX UNITS-NEW	1005 0003 BLDG EXTERIOR SHEATHING 1018 0001 BLDG INSULATION RES COMM: South garaged joist hangers fill all nail holes, remove RES COMM: damaged hanger.	4/19/21 APPROVED 4/19/21 APPROVED WITH EXCEPT	DJH DJH
20 00001315	8613 DAVIS BLVD 15 00 BLDG, DUPLEX UNITS-NEW	1018 0001 BLDG INSULATION	4/19/21 APPROVED	DJH
20 00003993	8169 PRECINCT LINE RD 12 00 BLDG, COMMERCIAL-NEW	1015 0001 BLDG SECONDS RES COMM: Laundry plbg s-trap X2.	4/19/21 APPROVED WITH EXCEPT	DJH
20 00004447	5665 TRAVELLER DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: Cap off open vents. Wrap PVC in concrete. Clean street/ RES COMM: alley/ trash. maintain erosion control. 1000 0004 BLDG ROUGH PLUMBING/GAS T	4/19/21 APPROVED WITH EXCEPT 4/19/21 APPROVED	MP MP
20 00004645	7364 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1015 0003 BLDG SECONDS RES COMM: Clean street, cannot have trash, construction debris, port RES COMM: a johns in streets. Repair erosion control on lots.	4/19/21 APPROVED WITH EXCEPT	MP
20 00004800	7229 SMITH FARM DR 10 00 BLDG, SF-NEW	1050 0001 BLDG SITE CONCRETE WORK	4/19/21 APPROVED	TC
20 00004944	7245 SMITH FARM DR 10 00 BLDG, SF-NEW	1050 0001 BLDG SITE CONCRETE WORK	4/19/21 APPROVED	TC
20 00005181	8413 FRANKLIN CT 10 00 BLDG, SF-NEW	1000 0002 BLDG ROUGH PLUMBING/GAS T	4/19/21 APPROVED	TC
21 00000109	6445 IRON HORSE BLVD 10A 00 BLDG, SF-TOWNHOME NEW	1047 0001 BLDG TEMPORARY GAS RELEAS	4/19/21 APPROVED	MP
21 00000110	6441 IRON HORSE BLVD 10A 00 BLDG, SF-TOWNHOME NEW	1047 0001 BLDG TEMPORARY GAS RELEAS	4/19/21 APPROVED	MP
21 00000111	6437 IRON HORSE BLVD 10 00 BLDG, SF-NEW	1047 0001 BLDG TEMPORARY GAS RELEAS	4/19/21 APPROVED	MP
21 00000112	6433 IRON HORSE BLVD 10A 00 BLDG, SF-TOWNHOME NEW	1047 0001 BLDG TEMPORARY GAS RELEAS	4/19/21 APPROVED	MP
21 00000113	6429 IRON HORSE BLVD 10A 00 BLDG, SF-TOWNHOME NEW	1047 0001 BLDG TEMPORARY GAS RELEAS	4/19/21 APPROVED	MP
21 00000114	6425 IRON HORSE BLVD 10A 00 BLDG, SF-TOWNHOME NEW	1047 0001 BLDG TEMPORARY GAS RELEAS RES COMM: Damaged gauge.	4/19/21 DISAPPROVED WITH PEN	MP
21 00000632	7384 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: Missing brick ledge barrier. Wrap hose bib in brick. RES COMM: Missing hurricane straps thru out. Missing hanger at top of RES COMM: stairs. Missing valley supports 2nd floor. Loose wires in RES COMM: living and garage. Framing at back door not ready. Fire RES COMM: block garage wall with living space above.	4/19/21 DISAPPROVED	MP
21 00000634	7340 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA RES COMM: Need temp power letter.	4/19/21 DISAPPROVED	MP
21 00000725	7505 REGAL LN 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T	4/19/21 APPROVED	MP

21 00000742	6425 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS	4/19/21 APPROVED	MP
21 00000743	6429 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS	4/19/21 APPROVED	MP
21 00000747	6433 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS RES COMM: No test on 2nd floor plbg or shower pan.	4/19/21 DISAPPROVED WITH PEN	MP
21 00000748	6437 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS	4/19/21 APPROVED	MP
21 00000749	6441 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS	4/19/21 APPROVED	MP
21 00001037	9133 CORDERO DR 10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION	4/19/21 APPROVED	TC
21 00002114	5528 CRAWFORD DR 10 00 BLDG, SF-NEW	1003 0002 BLDG TEMPORARY POLE	4/19/21 APPROVED	MP
21 00002117	5536 CRAWFORD DR 10 00 BLDG, SF-NEW	1003 0002 BLDG TEMPORARY POLE	4/19/21 APPROVED	MP
21 00002241	6719 MID CITIES BLVD 13 00 BLDG, COMMERCIAL RMDL/REPR	0000 0001 MISC INSPECTOR'S CHOICE REQ COMM: ELECTRICAL FINAL RES COMM: ELECTRICAL FINAL.	4/19/21 APPROVED	TC
	28C 00 ELEC, COMM/IND-RMDL/RPR/ADD	2090 0001 ELEC FINAL	4/19/21 APPROVED	TC
21 00002376	6848 MEADOW CREST DR 72R 00 FIRE SPRINKLER RESIDENTIAL SYS	5040 0002 FIRE SPRINKLER AIR/HYDRO RES COMM: Test on zero	4/19/21 DISAPPROVED	MP
21 00002377	6852 MEADOW CREST DR 72R 00 FIRE SPRINKLER RESIDENTIAL SYS	5040 0002 FIRE SPRINKLER AIR/HYDRO RES COMM: Test on zero	4/19/21 DISAPPROVED	MP
21 00002535	6737 CYLINDA SUE CIR WIND 00 BLDG, WINDOW REPLACEMENT>3	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/19/21 APPROVED	TC
21 00002557	6737 CYLINDA SUE CIR 45 00 FENCE-CHAIN/WOOD/OTHER	1502 0001 FENCE FINAL RES COMM: CAPS MISSING ON POSTS.	4/19/21 DISAPPROVED	TC
	45 00 FENCE-CHAIN/WOOD/OTHER	1502 0002 FENCE FINAL	4/19/21 APPROVED	TC
21 00002763	6536 RIDDLE DR 83 00 MECH, RES-WHOLE SYS. REPLACE	4090 0001 MECH MECHANICAL FINAL	4/19/21 APPROVED	GT
21 00002874	7304 MEADOWVIEW TER 37 00 POOL, BELOW/INGROUND	6010 0001 POOL STAKE OUT	4/19/21 APPROVED	TC
21 00002957	6621 WAKEFIELD RD 35 00 PLBG, MISCELLANEOUS	3090 0002 PLBG PLUMBING FINAL	4/19/21 APPROVED	TC
21 00002969	4036 HONEY LN 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection RES COMM: REPAIR ROTTEN WOOD ON EXTERIOR OF HOUSE & STORAGE BLDG.	4/19/21 DISAPPROVED	TC
21 00002972	4920 REDONDO ST 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection RES COMM: LOCK BAR MISSING ON PATIO DOOR. RES COMM: INSULATE COPPER PIPE ON A/C CONDENSER. RES COMM: EACH BEDROOM REQUIERS A SMOKE DETECTOR.	4/19/21 DISAPPROVED	TC
21 00002973	6309 ONYX DR N 35 00 PLBG, MISCELLANEOUS	3005 0001 PLBG PLUMBING ROUGH	4/19/21 APPROVED	TC
	35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/19/21 APPROVED	TC
21 00002984	7832 A IRISH DR 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection RES COMM: ON ENTRY DOOR LOCKED.	4/19/21 DISAPPROVED	TC
21 00003008	7605 DEEVER DR 24 00 ELEC, SERVICE CHANGE/ADD	2090 0001 ELEC FINAL	4/19/21 APPROVED	GT

INSPECTION HISTORY REPORT

Friday, April 16, 2021

APPLICATION	PROPERTY ADDRESS/PERMIT	INSPECTION	RESULT DATE/STATUS	INSPECTOR
17 00000929	9000 COURTENAY ST 17 00 BLDG, MF-NEW	1090 0002 BLDG FINAL-BUILDING DEPT RES COMM: 2nd floor, M.E.p.s unit only punch list made.	4/16/21 DISAPPROVED	DJH
19 00002675	6520 BROWNING DR 12 00 BLDG, COMMERCIAL-NEW	1018 0004 BLDG INSULATION RES COMM: 2nd floor.	4/16/21 APPROVED	DJH
20 00003375	6901 DAVIS BLVD 12 00 BLDG, COMMERCIAL-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA	4/16/21 APPROVED	DJH
20 00003668	7937 SMITHFIELD RD 10 00 BLDG, SF-NEW	1015 0003 BLDG SECONDS RES COMM: finish nails in stud shoes. OK to insulate. Will need brick RES COMM: tie inspection and concrete cut out repair inspections.	4/16/21 APPROVED WITH EXCEPT	MP
20 00003808	8313 SAYERS LN 10 00 BLDG, SF-NEW	1090 0002 BLDG FINAL-BUILDING DEPT	4/16/21 APPROVED	MP
20 00004645	7364 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS RES COMM: Corrections not made. No test on water and RES COMM: leak is over the garage	4/16/21 DISAPPROVED looks like a	MP
20 00005303	5900 RICHMOND DR 37 00 POOL, BELOW/INGROUND	6090 0002 POOL FINAL	4/16/21 APPROVED	TC
21 00000454	9300 WESTERN RIDGE TR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1047 0001 BLDG TEMPORARY GAS RELEAS 1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: Master tub only-ok	4/16/21 APPROVED 4/16/21 PARTIALLY APPROVED	MP MP
21 00001220	7716 SHADOW WOOD DR 11 00 BLDG, SF/MINOR REMODEL 50SF+ 11 00 BLDG, SF/MINOR REMODEL 50SF+	1000 0002 BLDG ROUGH PLUMBING/GAS T 1015 0001 BLDG SECONDS	4/16/21 APPROVED 4/16/21 APPROVED	MP MP
21 00001284	7304 BOCA RATON DR 37 00 POOL, BELOW/INGROUND 37 00 POOL, BELOW/INGROUND	6030 0001 POOL DECK STEEL & BONDING 6040 0001 POOL PLUMBING/GAS/P TRAP RES COMM: NO PERMIT. RES COMM: NO INSPECTION MADE.	4/16/21 APPROVED 4/16/21 DISAPPROVED	TC TC
21 00001453	5121 RUFÉ SNOW DR 100 12A 00 BLDG, COMMERCIAL-ADDITION/TFO	1090 0003 BLDG FINAL-BUILDING DEPT	4/16/21 APPROVED	DJH
21 00002150	8408 EMERALD CIR 37 00 POOL, BELOW/INGROUND	6020 0002 POOL BELLY STEEL/BONDING	4/16/21 APPROVED	TC
21 00002200	7416 BELLA LN 37 00 POOL, BELOW/INGROUND	6020 0001 POOL BELLY STEEL/BONDING	4/16/21 APPROVED	TC
21 00002202	8313 SAYERS LN 32R 00 PLBG, RESIDENTIAL IRRIGATION	3003 0001 PLBG LAWN IRRIGATION	4/16/21 APPROVED	MP
21 00002321	6128 KESSLER DR 10 00 BLDG, SF-NEW	1000 0002 BLDG ROUGH PLUMBING/GAS T	4/16/21 APPROVED	DJH
21 00002479	9004 BELSHIRE DR 35 00 PLBG, MISCELLANEOUS	3090 0002 PLBG PLUMBING FINAL	4/16/21 APPROVED	GT
21 00002502	7109 TIMBERLANE DR 35 00 PLBG, MISCELLANEOUS	3090 0002 PLBG PLUMBING FINAL	4/16/21 APPROVED	TC
21 00002612	6820 FAIR MEADOWS DR 11A 00 BLDG, SF/MINOR REMODEL <=50SF	1010 0001 BLDG FRAMING RES COMM: Need a plumbing permit and an electrical permit.	4/16/21 APPROVED	GT
21 00002653	9135 BOULEVARD 26 51R 00 SIGN, MONUMENT REFACÉ	7003 0001 SIGN FINAL	4/16/21 APPROVED	DJH
21 00002708	9021 VALLEY VIEW DR 24 00 ELEC, SERVICE CHANGE/ADD	2090 0001 ELEC FINAL	4/16/21 APPROVED	GT
21 00002795	8313 SAYERS LN 45 00 FENCE-CHAIN/WOOD/OTHER	1502 0001 FENCE FINAL	4/16/21 APPROVED	MP
21 00002804	6217 WINTER PARK DR 83 00 MECH, RES-WHOLE SYS. REPLACE	4090 0001 MECH MECHANICAL FINAL	4/16/21 APPROVED	GT

21 00002819	5121 RUFÉ SNOW DR 100 01A 00 C OF O - NEW/ADDITION/INI TFO	1095 0001 BLDG CERTIFICATE OF OCCY	4/16/21 APPROVED	DJH
21 00002896	6737 CYLINDA SUE CIR 24 00 ELEC, SERVICE CHANGE/ADD	2090 0002 ELEC FINAL	4/16/21 APPROVED	TC
21 00002927	3316 TOURIST DR 35 00 PLBG, MISCELLANEOUS 35 00 PLBG, MISCELLANEOUS	3005 0001 PLBG PLUMBING ROUGH 3090 0001 PLBG PLUMBING FINAL	4/16/21 APPROVED 4/16/21 APPROVED	TC TC
21 00002942	7613 TERESA CT 35 00 PLBG, MISCELLANEOUS	3005 0001 PLBG PLUMBING ROUGH RES COMM: PROVIDE PHOTOS. RES COMM: PROVIDE TEST ON REPAIR.	4/16/21 DISAPPROVED	TC
21 00002957	6621 WAKEFIELD RD 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL RES COMM: NO ENTRY.	4/16/21 DISAPPROVED	TC

INSPECTION HISTORY REPORT
Thursday, April 15, 2021

<u>APPLICATION</u>	<u>PROPERTY ADDRESS/PERMIT</u>	<u>INSPECTION</u>	<u>RESULT DATE/STATUS</u>	<u>INSPECTOR</u>
19 00002649	6496 IRON HORSE BLVD 17 00 BLDG, MF-NEW	1041 0002 BLDG BRICK TIE INSPECTION RES COMM: Lath north wall.	4/15/21 APPROVED	DJH
19 00002657	6490 IRON HORSE BLVD 12 00 BLDG, COMMERCIAL-NEW	1050 0002 BLDG SITE CONCRETE WORK RES COMM: southside walkway.	4/15/21 APPROVED	DJH
20 00001312	8609 DAVIS BLVD 16 00 BLDG, TRIPLEX/QUAD-NEW	1017 0001 BLDG FIRE WALLS/ASSEMBLIE REQ COMM: A RES COMM: SEAL PARTY WALL IN THE ATTIC.	4/15/21 APPROVED WITH EXCEPT	DJH
	16 00 BLDG, TRIPLEX/QUAD-NEW	1018 0001 BLDG INSULATION RES COMM: PROVIDE R-VALUE FOR PARTY WALLS.	4/15/21 APPROVED WITH EXCEPT	DJH
20 00001315	8613 DAVIS BLVD 15 00 BLDG, DUPLEX UNITS-NEW	1015 0001 BLDG SECONDS RES COMM: Joist hanger garage missing both ends. Fire block party RES COMM: wall at cross wall. Ok to insulate.	4/15/21 APPROVED WITH EXCEPT	DJH
20 00003446	6850 RUFÉ SNOW DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/15/21 APPROVED	MP
20 00004351	8305 SOUTHRIDGE CT 37 00 POOL, BELOW/INGROUND	6090 0001 POOL FINAL RES COMM: PROVIDE FINAL GRADE & DRAINAGE SURVEY FOR FINAL SHOWING RES COMM: DRAINAGE AWAY FROM NEIGHBORING PROPERTY.	4/15/21 DISAPPROVED	TC
20 00004645	7364 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: Walked house with Cooper, see list in file. Not ready.	4/15/21 DISAPPROVED	MP
20 00005071	6309 ROVER LN 10 00 BLDG, SF-NEW	1090 0002 BLDG FINAL-BUILDING DEPT RES COMM: Dishwasher hose must be to top of cabinet when used for air RES COMM: gap.	4/15/21 APPROVED WITH EXCEPT	MP
20 00005137	6801 SWITCHBACK TR 10 00 BLDG, SF-NEW	1090 0002 BLDG FINAL-BUILDING DEPT RES COMM: Missing gfcı protection for tankless on exterior wall. RES COMM: Label gfcı's in dining. Missing trees in ROW. 18' parking RES COMM: required in garage. Workers on site making repairs.	4/15/21 APPROVED WITH EXCEPT	MP
21 00000040	6856 MEADOW CREST DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS	4/15/21 APPROVED	MP
	10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION REQ COMM: app	4/15/21 APPROVED	MP
21 00000049	6844 MEADOW CREST DR 10 00 BLDG, SF-NEW	1015 0004 BLDG SECONDS	4/15/21 APPROVED	MP
	10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION	4/15/21 APPROVED	MP
21 00000052	6848 MEADOW CREST DR 10 00 BLDG, SF-NEW	1015 0004 BLDG SECONDS REQ COMM: ap	4/15/21 APPROVED	MP
	10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION	4/15/21 APPROVED	MP
21 00000053	6852 MEADOW CREST DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS	4/15/21 APPROVED	MP
	10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION	4/15/21 APPROVED	MP
21 00000057	6840 MEADOW CREST DR 10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION	4/15/21 APPROVED	MP
21 00000760	6808 SWITCHBACK TR 10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION	4/15/21 APPROVED	MP
21 00001039	7336 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1041 0001 BLDG BRICK TIE INSPECTION RES COMM: Brick ties, soffits and wrap ok on exterior	4/15/21 APPROVED	MP
21 00001197	7104 COOK CIR 37 00 POOL, BELOW/INGROUND	6080 0001 POOL PRE-PLASTER RES COMM: PROVIDE FINAL GRADE & DRAINAGE SURVEY FOR POOL FINAL. RES COMM: REMOVE ROCK FROM STREET. RES COMM: GATE NOT SELF CLOSING. RES COMM: NO ENTRY TO CHECK BACK DOOR ALARMS.	4/15/21 DISAPPROVED	TC
21 00001208	6345 DAVIS BLVD 13 00 BLDG, COMMERCIAL RMDL/REPR	1090 0002 BLDG FINAL-BUILDING DEPT	4/15/21 APPROVED	DJH

21 00001605	6801 SWITCHBACK TR 45 00 FENCE-CHAIN/WOOD/OTHER	1502 0001 FENCE FINAL	4/15/21 APPROVED	MP
21 00001620	7613 FRANKIE B ST 37 00 POOL, BELOW/INGROUND	6010 0001 POOL STAKE OUT	4/15/21 APPROVED	TC
21 00002240	6557 NORTHERN DANCER DR 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0002 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/15/21 APPROVED	MP
21 00002301	5909 BARTON SPRINGS DR 11 00 BLDG, SF/MINOR REMODEL 50SF+	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: PIERS	4/15/21 APPROVED	TC
	11 00 BLDG, SF/MINOR REMODEL 50SF+	1015 0001 BLDG SECONDS RES COMM: ADD HURRICANE TIES TO RAFTERS.	4/15/21 APPROVED WITH EXCEPT	TC
21 00002321	6128 KESSLER DR 10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE	4/15/21 APPROVED	MP
	10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Survey must show layout and setbacks between front of house RES COMM: and patios. Secure and break off tamper screw on vacuum RES COMM: breaker. Cannot have open test tee at tap. OK to pull test RES COMM: before rain.	4/15/21 DISAPPROVED	MP
21 00002328	8805 GRAND AVE 10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE	4/15/21 APPROVED	MP
21 00002456	8309 THORNHILL DR 42A 00 DECK/PATIO W/ COVER	1001 0001 BLDG STRUCTURAL CONCRETE	4/15/21 APPROVED	TC
21 00002486	6801 SWITCHBACK TR 32R 00 PLBG, RESIDENTIAL IRRIGATION	3003 0001 PLBG LAWN IRRIGATION	4/15/21 APPROVED	MP
21 00002622	8329 SADDLEBROOK DR 37 00 POOL, BELOW/INGROUND	6010 0001 POOL STAKE OUT RES COMM: LEAVE PLANS OUTSIDE IN BAG	4/15/21 APPROVED WITH EXCEPT	TC
21 00002672	6609 MEADOWRIDGE CT 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/15/21 APPROVED	DJH
21 00002697	7337 PLUMWOOD DR 28S 00 ELEC, PHOTOVOLTAIC (SOLAR)	2015 0001 ELEC SERVICE UPGRADE RES COMM: PROVIDE 2 MEANS OF GROUNDING THRU ELECTRICAL PANEL.	4/15/21 DISAPPROVED	TC
21 00002739	6716 SMITHFIELD RD 3 01C 00 C OF O-NEW OCCUPANT/NEW USE	1046 0001 BLDG TEMPORARY ELEC RELEA	4/15/21 APPROVED	DJH
21 00002787	6425 NORTHERN DANCER DR 72R 00 FIRE SPRINKLER RESIDENTIAL SYS	5040 0001 FIRE SPRINKLER AIR/HYDRO	4/15/21 APPROVED	MP
21 00002791	6429 NORTHERN DANCER DR 72R 00 FIRE SPRINKLER RESIDENTIAL SYS	5040 0001 FIRE SPRINKLER AIR/HYDRO	4/15/21 APPROVED	MP
21 00002792	6433 NORTHERN DANCER DR 72R 00 FIRE SPRINKLER RESIDENTIAL SYS	5040 0001 FIRE SPRINKLER AIR/HYDRO	4/15/21 APPROVED	MP
21 00002793	6437 NORTHERN DANCER DR 72R 00 FIRE SPRINKLER RESIDENTIAL SYS	5040 0001 FIRE SPRINKLER AIR/HYDRO	4/15/21 APPROVED	MP
21 00002794	6441 NORTHERN DANCER DR 72R 00 FIRE SPRINKLER RESIDENTIAL SYS	5040 0001 FIRE SPRINKLER AIR/HYDRO	4/15/21 APPROVED	MP
21 00002834	8212 NORTHEAST PKWY 102 01C 00 C OF O-NEW OCCUPANT/NEW USE	1046 0001 BLDG TEMPORARY ELEC RELEA RES COMM: Electric panels are blocked. Panels have open slots. Exits RES COMM: are blocked. Fire extinguisher blocked. Support electric RES COMM: flex m.c. over office. Restroom toilet seats must be open RES COMM: end, u-shaped.	4/15/21 APPROVED WITH EXCEPT	DJH
21 00002850	6340 BRYNWYCK LN 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/15/21 APPROVED	TC
21 00002854	6850 RUFÉ SNOW DR 35 00 PLBG, MISCELLANEOUS	3090 0002 PLBG PLUMBING FINAL RES COMM: Leak detected after 15 minute test. Double check to make RES COMM: sure and re-set gauge for another 15 minutes. System still RES COMM: leaking.	4/15/21 DISAPPROVED	MP
000 000	35 00 PLBG, MISCELLANEOUS	3090 0003 PLBG PLUMBING FINAL	4/15/21 APPROVED	MP
21 00002856	7900 SHADY OAKS DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/15/21 APPROVED	GT
21 00002896	6737 CYLINDA SUE CIR			

24	00 ELEC, SERVICE CHANGE/ADD	2090 0001 ELEC FINAL RES COMM: PROVIDE 2 MEANS OF GROUNDING THRU ELECTRICAL PANEL. RES COMM: ELECTRICAL OUTLET AT WASHER NOT GFCI PROTECTED.	4/15/21 DISAPPROVED	TC
21 00002909	6424 WAKEFIELD RD 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/15/21 APPROVED	TC
21 00002910	6800 GLENHURST DR 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection RES COMM: INSULATE COPPER PIPE ON A/C CONDENSER.	4/15/21 APPROVED WITH EXCEPT	TC
21 00002911	5404 ROBERTA DR 83 00 MECH, RES-WHOLE SYS. REPLACE	4090 0001 MECH MECHANICAL FINAL	4/15/21 APPROVED	GT

INSPECTION HISTORY REPORT
Wednesday, April 14, 2021

<u>APPLICATION</u>	<u>PROPERTY ADDRESS/PERMIT</u>	<u>INSPECTION</u>	<u>RESULT DATE/STATUS</u>	<u>INSPECTOR</u>
17 00000929	9000 COURTENAY ST 17 00 BLDG, MF-NEW	1080 0001 BLDG LANDSCAPING & IRRIGA RES COMM: see finals.	4/14/21 APPROVED WITH EXCEPT	DJH
	17 00 BLDG, MF-NEW	1015 0006 BLDG SECONDS RES COMM: was done witi no follow up inspection.	4/14/21 APPROVED WITH EXCEPT	DJH
	17 00 BLDG, MF-NEW	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: 3rd floor units only inspected, punch list made.	4/14/21 DISAPPROVED	DJH
19 00002643	7132 STARNES RD 11 00 BLDG, SF/MINOR REMODEL 50SF+	1090 0001 BLDG FINAL-BUILDING DEPT	4/14/21 DISAPPROVED	MLS
19 00002657	6490 IRON HORSE BLVD 12 00 BLDG, COMMERCIAL-NEW	1014 0010 BLDG ELEC ROUGH-BURY/WALL RES COMM: U.E at pool equipment- east side, tree wells and oncor at RES COMM: west side.	4/14/21 APPROVED	DJH
20 00001313	8611 DAVIS BLVD 15 00 BLDG, DUPLEX UNITS-NEW	1015 0001 BLDG SECONDS RES COMM: Fire block party wall at cross section walls. Ok to RES COMM: insulate.	4/14/21 APPROVED WITH EXCEPT	DJH
20 00001815	8001 NORTHEAST PKWY 12 00 BLDG, COMMERCIAL-NEW	1025 0004 BLDG CIELING COVER UP RES COMM: hard ceiling section C 2nd floor, 3 areas.	4/14/21 APPROVED	DJH
20 00001989	7100 RUFÉ SNOW DR 100 13 00 BLDG, COMMERCIAL RMDL/REPR	1018 0001 BLDG INSULATION RES COMM: wall insulation.	4/14/21 APPROVED	DJH
20 00004452	5644 TRAVELLER DR 10 00 BLDG, SF-NEW	1050 0001 BLDG SITE CONCRETE WORK	4/14/21 APPROVED	MP
20 00005072	6313 ROVER LN 10 00 BLDG, SF-NEW	1090 0002 BLDG FINAL-BUILDING DEPT RES COMM: Garage steps not to code Cannot be more than 3/8" off total RES COMM: rise, you are at 1". See 2x4 with tag.	4/14/21 DISAPPROVED	MP
20 00005079	5525 TRAVELLER DR 10 00 BLDG, SF-NEW	1050 0001 BLDG SITE CONCRETE WORK	4/14/21 APPROVED	MP
20 00005271	6208 ABBOTT AVE 37 00 POOL, BELOW/INGROUND	6080 0001 POOL PRE-PLASTER	4/14/21 APPROVED	TC
20 00005401	6925 CRANE RD 11 00 BLDG, SF/MINOR REMODEL 50SF+	1015 0003 BLDG SECONDS RES COMM: windows	4/14/21 APPROVED	GT
20 00005463	8536 FRESH MEADOWS RD 10 00 BLDG, SF-NEW	1015 0003 BLDG SECONDS RES COMM: Corrections not made. Missing front door. Master shower not RES COMM: ready for inspections and master bay window torn apart.	4/14/21 DISAPPROVED WITH PEN	MP
21 00000714	6925 CRANE RD 11 00 BLDG, SF/MINOR REMODEL 50SF+	1015 0002 BLDG SECONDS RES COMM: disconnect electric,water and sewer	4/14/21 APPROVED	GT
21 00000743	6429 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: Need hydro inspections. Dry in roof. Fire block stairs and RES COMM: front wall. Fill shower pan for inspections	4/14/21 DISAPPROVED	MP
21 00000747	6433 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: Need hydro inspections. Water test low and fill shower for RES COMM: inspections.	4/14/21 DISAPPROVED	MP
21 00000992	5920 CAMBRIDGE DR 11 00 BLDG, SF/MINOR REMODEL 50SF+	1001 0001 BLDG STRUCTURAL CONCRETE	4/14/21 APPROVED	TC
21 00001037	9133 CORDERO DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS RES COMM: Corrections not made. Secure wires at box. Missing barrier RES COMM: on brick ledge. Repair trash bin.	4/14/21 APPROVED WITH EXCEPT	MP
21 00001220	7716 SHADOW WOOD DR 11 00 BLDG, SF/MINOR REMODEL 50SF+	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Half bath tap ok. Main line in room ok. Bathroom rough not RES COMM: ready.	4/14/21 PARTIALLY APPROVED	MP
21 00001233	6809 CRANE RD			

	10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE	4/14/21 APPROVED	TC
21 00001387	8572 FRESH MEADOWS RD 37 00 POOL, BELOW/INGROUND	6040 0002 POOL PLUMBING/GAS/P TRAP	4/14/21 APPROVED	MP
21 00001388	6241 SHERBERT DR 37 00 POOL, BELOW/INGROUND	6030 0001 POOL DECK STEEL & BONDING RES COMM: Top of pool coping must be 3" below house finish floor RES COMM: elevation.	4/14/21 DISAPPROVED	DJH
21 00001740	7212 CROSS KEYS CIR 37 00 POOL, BELOW/INGROUND	6040 0002 POOL PLUMBING/GAS/P TRAP	4/14/21 APPROVED	TC
21 00001827	8104 THORNWOOD DR 11 00 BLDG, SF/MINOR REMODEL 50SF+	1010 0001 BLDG FRAMING	4/14/21 APPROVED	TC
21 00002110	8709 MONTROSE DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1001 0002 BLDG STRUCTURAL CONCRETE RES COMM: Piers ok, see engineers letter on file. 1000 0002 BLDG ROUGH PLUMBING/GAS T	4/14/21 PARTIALLY APPROVED 4/14/21 APPROVED	MP MP
21 00002114	5528 CRAWFORD DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T 1003 0001 BLDG TEMPORARY POLE RES COMM: No ground rod	4/14/21 APPROVED 4/14/21 DISAPPROVED	MP MP
21 00002115	5532 CRAWFORD DR 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T	4/14/21 APPROVED	MP
21 00002117	5536 CRAWFORD DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T 1003 0001 BLDG TEMPORARY POLE RES COMM: no ground rod	4/14/21 APPROVED 4/14/21 DISAPPROVED	MP MP
21 00002119	5540 CRAWFORD DR 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T	4/14/21 APPROVED	MP
21 00002120	5544 CRAWFORD DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T 1003 0001 BLDG TEMPORARY POLE	4/14/21 APPROVED 4/14/21 APPROVED	MP MP
21 00002121	5548 CRAWFORD DR 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T	4/14/21 APPROVED	MP
21 00002122	5552 CRAWFORD DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T 1003 0001 BLDG TEMPORARY POLE	4/14/21 APPROVED 4/14/21 APPROVED	MP MP
21 00002147	8572 FRESH MEADOWS RD 11 00 BLDG, SF/MINOR REMODEL 50SF+	1042 0001 BLDG GAS PRESSURE TEST	4/14/21 APPROVED	MP
21 00002236	8809 KIRK LN 24 00 ELEC, SERVICE CHANGE/ADD	2005 0001 ELEC UNDERGROUND RES COMM: 230' from meter to well head.	4/14/21 APPROVED	DJH
21 00002334	6138 MAYFAIR MEWS 24 00 ELEC, SERVICE CHANGE/ADD	2005 0001 ELEC UNDERGROUND RES COMM: out of utility easement.	4/14/21 DISAPPROVED	DJH
21 00002454	6824 RIDGETOP RD 14 00 BLDG, SF FOUNDATION	1037 0003 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/14/21 APPROVED	TC
21 00002487	4709 REDONDO ST 14 00 BLDG, SF FOUNDATION	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/14/21 APPROVED	TC
21 00002509	7121 ROMFORD WY 14 00 BLDG, SF FOUNDATION	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/14/21 APPROVED	TC
21 00002654	7613 HIGHTOWER DR 14 00 BLDG, SF FOUNDATION	1037 0002 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/14/21 APPROVED	TC
21 00002699	7105 BERMUDA CT			

	285 00 ELEC, PHOTOVOLTAIC (SOLAR)	2015 0002 ELEC SERVICE UPGRADE	4/14/21 APPROVED	TC
21 00002729	6013 CLUB HOUSE DR			
	83 00 MECH, RES-WHOLE SYS. REPLACE	4090 0001 MECH MECHANICAL FINAL	4/14/21 APPROVED	GT
21 00002731	7525 OAK PARK DR			
	83 00 MECH, RES-WHOLE SYS. REPLACE	4090 0001 MECH MECHANICAL FINAL	4/14/21 APPROVED	GT
21 00002831	6401 SIMMONS RD			
	83 00 MECH, RES-WHOLE SYS. REPLACE	4090 0001 MECH MECHANICAL FINAL	4/14/21 APPROVED	GT
21 00002841	8437 EMERALD CIR			
	35 00 PLBG, MISCELLANEOUS	3005 0001 PLBG PLUMBING ROUGH RES COMM: NO ENTRY.	4/14/21 DISAPPROVED	TC
21 00002882	5904 HOLIDAY LN D			
	01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/14/21 APPROVED	TC
21 00002884	7108 HERMAN JARED DR			
	01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/14/21 APPROVED	TC

INSPECTION HISTORY REPORT
Tuesday, April 13, 2021

<u>APPLICATION</u>	<u>PROPERTY ADDRESS/PERMIT</u>	<u>INSPECTION</u>	<u>RESULT DATE/STATUS</u>	<u>INSPECTOR</u>
19 00002675	6520 BROWNING DR 12 00 BLDG, COMMERCIAL-NEW	1035 0001 BLDG DRYWALL REQ COMM: Shear wall 2nd floor area 5B RES COMM: Shear wall 2cd floor area 5B	4/13/21 APPROVED	GT
20 00001815	8001 NORTHEAST PKWY 12 00 BLDG, COMMERCIAL-NEW	1035 0001 BLDG DRYWALL RES COMM: Fire wall area C 1st floor	4/13/21 APPROVED WITH EXCEPT	GT
20 00004039	6572 IRON HORSE BLVD 10 00 BLDG, SF-NEW	1047 0001 BLDG TEMPORARY GAS RELEASES RES COMM: Gas not ready, missing stops, plumbers on site still RES COMM: working.	4/13/21 DISAPPROVED	MP
	10 00 BLDG, SF-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA	4/13/21 APPROVED	MP
20 00004608	8309 REGENCY DR 37 00 POOL, BELOW/INGROUND	6080 0001 POOL PRE-PLASTER RES COMM: PROVIDE FINAL GRADE & DRAINAGE SURVEY FOR POOL FINAL. RES COMM: GATE NOT SELF CLOSING. RES COMM: NEED APPROVED ALARM ON BACK DOOR.	4/13/21 DISAPPROVED	TC
20 00005071	6309 ROVER LN 10 00 BLDG, SF-NEW	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: Need to have handicap parking for model and sign final RES COMM: before last final in this building. Gas smell in kitchen RES COMM: Caulk around halfbath commode. Caulk between brick and RES COMM: aening over front door. Seal off vent a hood in cabinet and RES COMM: ceiling. Clean out disposal and missing air gap on RES COMM: dishwasher.	4/13/21 DISAPPROVED	MP
20 00005132	5660 TRAVELLER DR 10 00 BLDG, SF-NEW	1018 0002 BLDG INSULATION	4/13/21 APPROVED	MP
20 00005181	8413 FRANKLIN CT 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Repair silt fencing and add wire mess to support silt RES COMM: fence. Need trash bin on jobsite. No city plans or form RES COMM: board survey found on site, no inspections made.	4/13/21 DISAPPROVED	MP
20 00005467	8533 FRESH MEADOWS RD 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING RES COMM: Clean up loose trash on lot and blowing in neighborhood and RES COMM: install trash bin on lot. RES COMM: No inspections made	4/13/21 DISAPPROVED	MP
21 00000742	6425 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: Draft stop duct chases on 2nd floor. Fill shower pan for RES COMM: inspections. Fire rock up to roof deck. Need hydro RES COMM: inspections.	4/13/21 DISAPPROVED	MP
21 00000891	6436 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1000 0002 BLDG ROUGH PLUMBING/GAS T	4/13/21 APPROVED	MP
21 00000896	6432 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1000 0002 BLDG ROUGH PLUMBING/GAS T	4/13/21 APPROVED	MP
21 00000898	6428 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1000 0002 BLDG ROUGH PLUMBING/GAS T	4/13/21 APPROVED	MP
21 00000899	6424 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1000 0002 BLDG ROUGH PLUMBING/GAS T	4/13/21 APPROVED	MP
21 00000910	6500 BOLD RULER LN 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: 6500-6508 Bold Ruler- ufers cannot be in contact with RES COMM: cables and must be in lower 2" of beams. 6508 commode in RES COMM: beam must be supported with proper fall. Need engineers RES COMM: inspection letter stamped and signed.	4/13/21 DISAPPROVED	MP
	10 00 BLDG, SF-NEW	1001 0002 BLDG STRUCTURAL CONCRETE	4/13/21 APPROVED WITH EXCEPT	MP
21 00000914	6508 BOLD RULER LN 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: Support commode and fix ufer	4/13/21 APPROVED WITH EXCEPT	MP
21 00000918	6504 BOLD RULER LN 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE	4/13/21 APPROVED WITH EXCEPT	MP
21 00001260	8704 WOODBURY CT 10 00 BLDG, SF-NEW	1000 0002 BLDG ROUGH PLUMBING/GAS T	4/13/21 APPROVED	MP
	10 00 BLDG, SF-NEW	1003 0002 BLDG TEMPORARY POLE	4/13/21 APPROVED	MP
21 00001285	8801 REDDING ST			

	10 00 BLDG, SF-NEW	1001 0002 BLDG STRUCTURAL CONCRETE	4/13/21 APPROVED	TC
21 00001722	5640 TOURIST DR 82 00 MECH, REMODEL/REPAIR/REPLACE	4090 0001 MECH MECHANICAL FINAL	4/13/21 APPROVED	GT
21 00002048	8520 FRESH MEADOWS RD 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: No water test on PVC RES COMM: No plbg permit on file.	4/13/21 DISAPPROVED WITH PEN	MP
	10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE	4/13/21 APPROVED	MP
21 00002053	8701 WOODBURY CT 10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE	4/13/21 APPROVED	MP
21 00002072	7604 AUBREY LN 37 00 POOL, BELOW/INGROUND	6030 0001 POOL DECK STEEL & BONDING	4/13/21 APPROVED	TC
21 00002110	8709 MONTROSE DR 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Ditches wet, water test low and 2" off main line in front RES COMM: is leaking.	4/13/21 DISAPPROVED	MP
21 00002325	6121 KESSLER DR 10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE	4/13/21 APPROVED	TC
21 00002326	6120 KESSLER DR 10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE	4/13/21 APPROVED	TC
21 00002327	6124 KESSLER DR 10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE	4/13/21 APPROVED	TC
21 00002416	6109 PRICE DR 14 00 BLDG, SF FOUNDATION	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS. RES COMM: NO WORK DONE	4/13/21 DISAPPROVED	TC
21 00002541	8516 BROOKRIDGE DR 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0002 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/13/21 APPROVED	TC
21 00002735	8545 NEIL CT 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/13/21 APPROVED	TC
21 00002766	5409 SCOTT DR 45 00 FENCE-CHAIN/WOOD/OTHER	1502 0001 FENCE FINAL	4/13/21 APPROVED	TC
21 00002809	4616 VANCE RD WIND 00 BLDG, WINDOW REPLACEMENT>3	1090 0001 BLDG FINAL-BUILDING DEPT	4/13/21 APPROVED	GT
21 00002832	8021 KANDY LN 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL RES COMM: T&P line can't run uphill. Don't see a pan or an auto RES COMM: shutoff	4/13/21 DISAPPROVED	GT
21 00002854	6850 RUFÉ SNOW DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL RES COMM: Gas test not holding.	4/13/21 DISAPPROVED	MP
21 00002866	7612 JEAN ANN DR 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/13/21 APPROVED	TC

INSPECTION HISTORY REPORT
Monday, April 12, 2021

<u>APPLICATION</u>	<u>PROPERTY ADDRESS/PERMIT</u>	<u>INSPECTION</u>	<u>RESULT DATE/STATUS</u>	<u>INSPECTOR</u>
19 00002675	6520 BROWNING DR 12 00 BLDG, COMMERCIAL-NEW	1018 0003 BLDG INSULATION RES COMM: 1st floor section B reinstall missing insulation	4/12/21 APPROVED WITH EXCEPT	GT
20 00003808	8313 SAYERS LN 10 00 BLDG, SF-NEW	1050 0003 BLDG SITE CONCRETE WORK RES COMM: Inspections done by P.W.	4/12/21 APPROVED WITH EXCEPT	MP
	10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION RES COMM: see final results, builder did not call for insulation RES COMM: inspections.	4/12/21 APPROVED WITH EXCEPT	MP
	10 00 BLDG, SF-NEW	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: Builder requested a punch list final per his inspection RES COMM: request left on the inspection line. Please see 2 page 25 RES COMM: item lists in file. Inspections completed for work RES COMM: completed. Fee due	4/12/21 DISAPPROVED WITH PEN	MP
20 00004463	7372 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1041 0001 BLDG BRICK TIE INSPECTION RES COMM: Missing fire fire for soffits, do not cover. Brick tie ok RES COMM: for siding only.	4/12/21 DISAPPROVED	MP
20 00004629	7360 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING	4/12/21 APPROVED	MP
20 00005132	5660 TRAVELLER DR 10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION RES COMM: No plans on site, energy plans must be on sites for RES COMM: inspections. Clean up trash along fence line along alley RES COMM: also behind occupied houses.	4/12/21 DISAPPROVED	MP
20 00005191	5517 TRAVELLER DR 10 00 BLDG, SF-NEW	1017 0001 BLDG FIRE WALLS/ASSEMBLIE RES COMM: No packet, clean up trash on lots. Int.firewall ok	4/12/21 APPROVED WITH EXCEPT	MP
20 00005381	8305 CABALLO DR 37 00 POOL, BELOW/INGROUND	6030 0001 POOL DECK STEEL & BONDING RES COMM: STEPS SHALL MEET BLDG CODE AT FINAL.	4/12/21 APPROVED	TC
21 00000523	8317 CABALLO DR 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING	4/12/21 APPROVED	MP
21 00000742	6425 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1005 0002 BLDG EXTERIOR SHEATHING	4/12/21 APPROVED	MP
21 00000743	6429 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING	4/12/21 APPROVED	MP
21 00000747	6433 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING	4/12/21 APPROVED	MP
21 00000748	6437 NORTHERN DANCER DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING 1015 0001 BLDG SECONDS RES COMM: Need hydro insection. Gas test leaking. Insulate water RES COMM: above front door. Add nails to spliced rafters per RES COMM: engineering. Fire block above garage wall.	4/12/21 APPROVED 4/12/21 DISAPPROVED	MP MP
21 00000749	6441 NORTHERN DANCER DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1005 0002 BLDG EXTERIOR SHEATHING 1015 0001 BLDG SECONDS RES COMM: Clean up trash on lotsa nd across the street. Fire block RES COMM: stairs. Master shower must be full and level for RES COMM: inspections. Need Hydro test, head placement ok.	4/12/21 APPROVED 4/12/21 DISAPPROVED	MP MP
21 00000891	6436 NORTHERN DANCER DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Water service not ready. 1003 0001 BLDG TEMPORARY POLE RES COMM: Already connected	4/12/21 DISAPPROVED 4/12/21 CANCELLED	MP MP
21 00000896	6432 NORTHERN DANCER DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Water service not ready 1003 0001 BLDG TEMPORARY POLE	4/12/21 DISAPPROVED 4/12/21 APPROVED	MP MP
21 00000898	6428 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Water service not ready.	4/12/21 DISAPPROVED	MP

	10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE	4/12/21 APPROVED	MP
21 00000899	6424 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Water service not ready.	4/12/21 DISAPPROVED	MP
	10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE	4/12/21 APPROVED	MP
21 00000960	8120 SHADOW WOOD DR 37 00 POOL, BELOW/INGROUND	6040 0001 POOL PLUMBING/GAS/P TRAP	4/12/21 APPROVED	TC
21 00001005	5555 RUFÉ SNOW DR 150 12A 00 BLDG, COMMERCIAL-ADDITION/TFO	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: wrap all plumbing pipes in plastic	4/12/21 APPROVED WITH EXCEPT	GT
21 00001285	8801 REDDING ST 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: Ufer spliced and up too high. Plbg not sleeved or properly RES COMM: sleeved thru out house. Cap off open vents.	4/12/21 DISAPPROVED	MP
	10 00 BLDG, SF-NEW	1050 0001 BLDG SITE CONCRETE WORK	4/12/21 APPROVED	MP
21 00001387	8572 FRESH MEADOWS RD 37 00 POOL, BELOW/INGROUND	6040 0001 POOL PLUMBING/GAS/P TRAP RES COMM: Work done without plumbing and electric permits.	4/12/21 DISAPPROVED WITH PEN	MP
21 00001619	8805 THORNDALÉ CT 37 00 POOL, BELOW/INGROUND	6040 0001 POOL PLUMBING/GAS/P TRAP	4/12/21 APPROVED	TC
21 00001740	7212 CROSS KEYS CIR 37 00 POOL, BELOW/INGROUND	6040 0001 POOL PLUMBING/GAS/P TRAP RES COMM: no plumbing permit. RES COMM: no inspection made.	4/12/21 DISAPPROVED	TC
21 00001808	6817 LITTLE RANCH RD 40A 00 BLDG, PERM ACCESSORY BUILDING	1001 0001 BLDG STRUCTURAL CONCRETE	4/12/21 APPROVED	TC
21 00001827	8104 THORNWOOD DR 11 00 BLDG, SF/MINOR REMODEL 50SF+ 11 00 BLDG, SF/MINOR REMODEL 50SF+	1000 0002 BLDG ROUGH PLUMBING/GAS T 1015 0001 BLDG SECONDS RES COMM: no one home , dog in back yard. RES COMM: no inspection made.	4/12/21 APPROVED 4/12/21 DISAPPROVED	TC TC
21 00001898	6904 ARBORBROOK DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/12/21 APPROVED	TC
21 00002150	8408 EMERALD CIR 37 00 POOL, BELOW/INGROUND	6020 0001 POOL BELLY STEEL/BONDING RES COMM: no electrical permit. RES COMM: no inspection made.	4/12/21 DISAPPROVED	TC
21 00002151	7525 REGAL LN 10 00 BLDG, SF-NEW	1003 0002 BLDG TEMPORARY POLE	4/12/21 APPROVED	MP
21 00002314	7513 REGAL LN 10 00 BLDG, SF-NEW	1003 0002 BLDG TEMPORARY POLE	4/12/21 APPROVED	MP
21 00002366	7616 LOLA DR 24 00 ELEC, SERVICE CHANGE/ADD	2090 0002 ELEC FINAL	4/12/21 APPROVED	TC
21 00002638	8315 THORNRIÐGE DR 35 00 PLBG, MISCELLANEOUS	3090 0003 PLBG PLUMBING FINAL	4/12/21 APPROVED WITH EXCEPT	GT
21 00002676	8612 FOXWOOD DR 285 00 ELEC, PHOTOVOLTAIC (SOLAR)	2015 0001 ELEC SERVICE UPGRADE	4/12/21 APPROVED	TC
21 00002677	6713 FAIR OAKS DR 285 00 ELEC, PHOTOVOLTAIC (SOLAR)	2015 0001 ELEC SERVICE UPGRADE	4/12/21 APPROVED	TC
21 00002699	7105 BERMUDA CT 285 00 ELEC, PHOTOVOLTAIC (SOLAR)	2015 0001 ELEC SERVICE UPGRADE RES COMM: provide 2 separate grounds through elc panel. RES COMM: secure ground to brick.	4/12/21 DISAPPROVED	TC
21 00002733	7120 OLDHAM PL 35 00 PLBG, MISCELLANEOUS 35 00 PLBG, MISCELLANEOUS	3005 0002 PLBG PLUMBING ROUGH 3090 0001 PLBG PLUMBING FINAL RES COMM: E-MAILED PHOTOS.	4/12/21 APPROVED 4/12/21 APPROVED	TC TC
21 00002734	5645 ROBINS WY 35 00 PLBG, MISCELLANEOU	S 3090 0001 PLBG PLUMBING FINAL	4/12/21 APPROVED	TC
21 00002742	8816 MAIN ST 43 00 PAVING SW/RES DW/DA	1090 0001 BLDG FINAL-BUILDING DEPT	4/12/21 APPROVED WITH EXCEPT	MP

RES COMM: Work done without permit. Permit obtained for zoning
RES COMM: compliance.

21 00002761	7705 CHASEWOOD DR 35 00 PLBG, MISCELLANEOUS	3005 0001 PLBG PLUMBING ROUGH RES COMM: TUNNEL 23' RES COMM: PROVIDE ENGINEERS COMPACTION LETTER FOR FINAL.	4/12/21 APPROVED WITH EXCEPT	TC
-------------	--	---	------------------------------	----

21 00002829	8008 SEVILLE DR 83 00 MECH, RES-WHOLE SYS. REPLACE	4090 0001 MECH MECHANICAL FINAL	4/12/21 APPROVED	GT
-------------	---	---------------------------------	------------------	----

21 00002845	7324 DEVILLE DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/12/21 APPROVED	TC
-------------	--	-------------------------------	------------------	----

INSPECTION HISTORY REPORT
Friday, April 9, 2021

<u>APPLICATION</u>	<u>PROPERTY ADDRESS/PERMIT</u>	<u>INSPECTION</u>	<u>RESULT DATE/STATUS</u>	<u>INSPECTOR</u>
19 00002674	6492 IRON HORSE BLVD 12 00 BLDG, COMMERCIAL-NEW	1041 0002 BLDG BRICK TIE INSPECTION RES COMM: Lath- north and west side of the building. Clean up all RES COMM: trash on the property.	4/09/21 APPROVED WITH EXCEPT	DJH
19 00004329	8721 EVERGLADE DR 11 00 BLDG, SF/MINOR REMODEL 50SF+	1090 0001 BLDG FINAL-BUILDING DEPT	4/09/21 APPROVED	TC
19 00005596	8701 NORTH TARRANT PKWY 12 00 BLDG, COMMERCIAL-NEW 12 00 BLDG, COMMERCIAL-NEW	1018 0001 BLDG INSULATION 1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: Sheetrock fire riser room. Need to apply for shell C.O. RES COMM: need fire dept inspection. open electric j-box at ceiling RES COMM: beam. west outlet no power. clean out storm drain grate RES COMM: inlet/curb inlet.	4/09/21 APPROVED 4/09/21 DISAPPROVED	DJH DJH
20 00001815	8001 NORTHEAST PKWY 12 00 BLDG, COMMERCIAL-NEW	1025 0003 BLDG CIELING COVER UP RES COMM: Hard deck 1st floor, access panels needed at 106, 104, 103 RES COMM: 102, 101, 106, 108, 105, 110, 120.	4/09/21 APPROVED WITH EXCEPT	DJH
20 00001989	7100 RUFÉ SNOW DR 100 13 00 BLDG, COMMERCIAL RMDL/REPR 13 00 BLDG, COMMERCIAL RMDL/REPR 13 00 BLDG, COMMERCIAL RMDL/REPR	1014 0002 BLDG ELEC ROUGH-BURY/WALL 1013 0001 BLDG MECHANICAL ROUGH 1011 0001 BLDG PLUMBING TOP OUT RES COMM: plbg vents have been cut out - 5 vents. Pex line support on RES COMM: 32" center, insulate pex line.	4/09/21 APPROVED 4/09/21 APPROVED 4/09/21 DISAPPROVED	DJH DJH DJH
20 00002975	7632 REGAL LN 10 00 BLDG, SF-NEW	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: Gas valve to cooktop must be accessible. Need final grade RES COMM: and drainage survey with ff,toc elevations and city RES COMM: compliance statement.	4/09/21 DISAPPROVED	MP
20 00002980	7644 REGAL LN 10 00 BLDG, SF-NEW	1090 0002 BLDG FINAL-BUILDING DEPT	4/09/21 APPROVED	MP
20 00004043	6568 IRON HORSE BLVD 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1046 0003 BLDG TEMPORARY ELEC RELEA 1047 0002 BLDG TEMPORARY GAS RELEAS	4/09/21 APPROVED 4/09/21 APPROVED	MP MP
20 00004447	5665 TRAVELLER DR 10 00 BLDG, SF-NEW	1000 0003 BLDG ROUGH PLUMBING/GAS T RES COMM: Need form board survey	4/09/21 DISAPPROVED	MP
20 00004452	5644 TRAVELLER DR 10 00 BLDG, SF-NEW	1046 0002 BLDG TEMPORARY ELEC RELEA	4/09/21 APPROVED	MP
20 00004463	7372 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING	4/09/21 APPROVED	MP
20 00004473	7912 HEATHERBROOK DR 37 00 POOL, BELOW/INGROUND	6090 0002 POOL FINAL	4/09/21 APPROVED	TC
20 00005080	5521 TRAVELLER DR 10 00 BLDG, SF-NEW	1017 0001 BLDG FIRE WALLS/ASSEMBLIE RES COMM: Int.firewalls ok	4/09/21 APPROVED	MP
20 00005187	6752 RIDGEWOOD DR 45 00 FENCE-CHAIN/WOOD/OTHER	1502 0001 FENCE FINAL	4/09/21 APPROVED	TC
20 00005320	8608 GLENBROOK DR 37 00 POOL, BELOW/INGROUND	6030 0001 POOL DECK STEEL & BONDING RES COMM: pavers.	4/09/21 APPROVED	TC
21 00000001	5121 RUFÉ SNOW DR 150 12A 00 BLDG, COMMERCIAL-ADDITION/TFO	1090 0002 BLDG FINAL-BUILDING DEPT	4/09/21 APPROVED	DJH
21 00000040	6856 MEADOW CREST DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS	4/09/21 DISAPPROVED	MP
21 00000052	6848 MEADOW CREST DR 10 00 BLDG, SF-NEW	1015 0003 BLDG SECONDS RES COMM: Foot vent 90's below flood rim and backfall on vent. Need RES COMM: hydro inspection and add heads under patios	4/09/21 DISAPPROVED	MP
21 00000057	6840 MEADOW CREST DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS RES COMM: Add heads under patios and need hydro test. Support valley RES COMM: in garage.	4/09/21 APPROVED WITH EXCEPT	MP
21 00000314	8309 SAYERS LN 10 00 BLDG, SF-NEW	1005 0003 BLDG EXTERIOR SHEATHING	4/09/21 APPROVED	MP

10	00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: Inspections completed for work completed. Clearly not ready RES COMM: for inspections.	4/09/21 DISAPPROVED WITH PEN	MP
21 00001005	5555 RUFÉ SNOW DR 150 12A 00 BLDG, COMMERCIAL-ADDITION/TFO	1014 0001 BLDG ELEC ROUGH-BURY/WALL RES COMM: Medical classroom.	4/09/21 APPROVED	DJH
21 00001037	9133 CORDERO DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: See completed list in file for work completed. Not ready.	4/09/21 DISAPPROVED WITH PEN	MP
21 00001101	8309 SANDY CT 37 00 POOL, BELOW/INGROUND	6040 0001 POOL PLUMBING/GAS/P TRAP	4/09/21 APPROVED	TC
21 00001373	8709 WOODBURY CT 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING	4/09/21 APPROVED	MP
21 00001453	5121 RUFÉ SNOW DR 100 12A 00 BLDG, COMMERCIAL-A	DDITION/TFO 1090 0002 BLDG FINAL-BUILDING DEPT RES COMM: Punch list made, temp C.O expires 4-23-21 for training RES COMM: only.	4/09/21 DISAPPROVED	DJH
21 00001647	7644 REGAL LN 32R 00 PLBG, RESIDENTIAL IRRIGATION	3003 0002 PLBG LAWN IRRIGATION	4/09/21 APPROVED	MP
21 00001811	5121 RUFÉ SNOW DR 150 01A 00 C OF O - NEW/ADDITION/INI TFO	1095 0001 BLDG CERTIFICATE OF OCCY	4/09/21 APPROVED	DJH
21 00002050	6250 NE LOOP 820 54 00 SIGN, WALL	7003 0001 SIGN FINAL	4/09/21 APPROVED	DJH
21 00002072	7604 AUBREY LN 37 00 POOL, BELOW/INGROUND 37 00 POOL, BELOW/INGROUND	6025 0002 POOL UNDERGROUND ELECTRIC 6040 0002 POOL PLUMBING/GAS/P TRAP	4/09/21 APPROVED 4/09/21 APPROVED	TC TC
21 00002518	7441 TIMBERHILL DR 14 00 BLDG, SF FOUNDATION	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/09/21 APPROVED	TC
21 00002594	8609 HIGHTOWER DR 75 00 FIRE TANKS/TEST/LP/FW/BLAST	5075 0001 FIRE PROPANE TANK	4/09/21 APPROVED	TC
21 00002690	8104 THORNWOOD DR 35 00 PLBG, MISCELLANEOUS	3001 0001 PLBG WATER/SEWER/GAS RELA	4/09/21 APPROVED	TC
21 00002732	5615 RUFÉ SNOW DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/09/21 APPROVED	GT
21 00002733	7120 OLDHAM PL 35 00 PLBG, MISCELLANEOUS	3005 0001 PLBG PLUMBING ROUGH RES COMM: provide photos of under house.	4/09/21 DISAPPROVED	TC
21 00002836	8133 VINE WOOD DR 90 00 COURTESY INSPECTION-BLDG	90 0001 COURTESY INSPECTION-BLDG RES COMM: need a remodel permit for master bath remodel with plumbing RES COMM: permit	4/09/21 APPROVED WITH EXCEPT	GT
21 00002844	7527 APRIL LN 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/09/21 APPROVED	TC

INSPECTION HISTORY REPORT

Thursday, April 8, 2021

<u>APPLICATION</u>	<u>PROPERTY ADDRESS/PERMIT</u>	<u>INSPECTION</u>	<u>RESULT DATE/STATUS</u>	<u>INSPECTOR</u>
18 00003165	6428 DAVIS BLVD BLDG3 12 00 BLDG, COMMERCIAL-NEW	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: Need to apply for a C.O. and have fire dept inspection. RES COMM: Concrete poured without city approval along southside RES COMM: beyond the property line. Brick expansion joints seal. RES COMM: Sewer clean outs missing screw caps and to grade. Clean up RES COMM: the yard. Bolts missing in wall girt brace. Place address RES COMM: on the building.	4/08/21 DISAPPROVED	DJH
19 00005726	8625 DAVIS BLVD 17 00 BLDG, MF-NEW	1005 0007 BLDG EXTERIOR SHEATHING REQ COMM: section #3 1st and 2nd floor.	4/08/21 APPROVED	DJH
20 00001312	8609 DAVIS BLVD 16 00 BLDG, TRIPLEX/QUAD-NEW	1015 0002 BLDG SECONDS RES COMM: Porch outlets metal boxes bonding required, porch columns RES COMM: fill all nail holes in plate. Joist hangers missing RES COMM: garage. ok to insulate.	4/08/21 APPROVED WITH EXCEPT	DJH
20 00001815	8001 NORTHEAST PKWY 12 00 BLDG, COMMERCIAL-NEW	1050 0013 BLDG SITE CONCRETE WORK RES COMM: Site concrete bus turn around, and piers for canopy front RES COMM: side 23 piers.	4/08/21 APPROVED	DJH
20 00004132	8417 PATRICKS PATH 37 00 POOL, BELOW/INGROUND 37 00 POOL, BELOW/INGROUND 37 00 POOL, BELOW/INGROUND	6025 0001 POOL UNDERGROUND ELECTRIC 6040 0001 POOL PLUMBING/GAS/P TRAP 0000 0001 MISC INSPECTOR'S CHOICE RES COMM: concret slab for pergolan	4/08/21 APPROVED 4/08/21 APPROVED 4/08/21 APPROVED	TC TC TC
20 00004447	5665 TRAVELLER DR 10 00 BLDG, SF-NEW	1000 0002 BLDG ROUGH PLUMBING/GAS T RES COMM: Correction not made from previous tag, see tag.	4/08/21 DISAPPROVED	MP
20 00004452	5644 TRAVELLER DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA RES COMM: Loose wires in wall under cooktop and at ac unit. Ground RES COMM: rod missing. Loose outlets in kitchen. 1047 0001 BLDG TEMPORARY GAS RELEASES	4/08/21 DISAPPROVED 4/08/21 APPROVED	MP MP
20 00004645	7364 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1041 0001 BLDG BRICK TIE INSPECTION	4/08/21 APPROVED	MP
20 00005072	6313 ROVER LN 10 00 BLDG, SF-NEW	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: See list in file	4/08/21 DISAPPROVED	MP
20 00005137	6801 SWITCHBACK TR 10 00 BLDG, SF-NEW	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: Missing ROW tree. North elevation drainage cannot run over RES COMM: wall. Missing gfci and lock out on tankless heaters. Steps RES COMM: in garage not to code. 18' minimum required parking in RES COMM: garage Locate foot vent. Label gfci in kitchen and dining.	4/08/21 DISAPPROVED	MP
21 00000049	6844 MEADOW CREST DR 10 00 BLDG, SF-NEW	1015 0003 BLDG SECONDS	4/08/21 DISAPPROVED	MP
21 00000053	6852 MEADOW CREST DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS	4/08/21 DISAPPROVED	MP
21 00000348	7701 REIS LN 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1005 0002 BLDG EXTERIOR SHEATHING RES COMM: See 2nds inspections. 1015 0001 BLDG SECONDS RES COMM: Inside only, outside sheathing and firewalls must be RES COMM: approved prior to 2nds. 1hr walls required up to roof deck. RES COMM: Rear walls and windows required sound proofing, no labels RES COMM: on windows. Need hydro inspections after heads installed. RES COMM: Nail plate 1" pex. Missing duct chase in master closet.	4/08/21 APPROVED WITH EXCEPT 4/08/21 DISAPPROVED	MP MP
21 00000349	7705 REIS LN 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING REQ COMM: ae RES COMM: see 2nds 1015 0001 BLDG SECONDS RES COMM: Sheathing and firewalls must be approved prior to 2nds. RES COMM: Sound proofing required on rear. Sprinkler heads missing RES COMM: under patios and need hydro inspections. 3" pvc out of wall RES COMM: in garage. Missing outlet on 2nd landing. Check for leak by	4/08/21 APPROVED WITH EXCEPT 4/08/21 DISAPPROVED	MP MP

RES COMM: master shower.

21 0000633	7316 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS 1018 0001 BLDG INSULATION	4/08/21 APPROVED 4/08/21 APPROVED	MP MP
21 00001039	7336 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING	4/08/21 APPROVED	MP
21 00001156	6800 SWALLOW LN 37 00 POOL, BELOW/INGROUND	6020 0004 POOL BELLY STEEL/BONDING	4/08/21 APPROVED	TC
21 00001281	7241 SMITH FARM DR 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING RES COMM: Finish staples at seams.	4/08/21 APPROVED WITH EXCEPT	MP
21 00001360	8213 FORREST LN 37 00 POOL, BELOW/INGROUND	6020 0004 POOL BELLY STEEL/BONDING	4/08/21 APPROVED	TC
21 00001432	8528 DAVIS BLVD 150 13 00 BLDG, COMMERCIAL RMDL/REPR 13 00 BLDG, COMMERCIAL RMDL/REPR	1014 0001 BLDG ELEC ROUGH-BURY/WALL 1010 0002 BLDG FRAMING	4/08/21 APPROVED 4/08/21 APPROVED	DJH DJH
21 00001685	7621 IRA DR 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE	4/08/21 APPROVED	TC
21 00001828	7016 RIDGE LINE DR 40A 00 BLDG, PERM ACCESSORY BUILDING	1090 0001 BLDG FINAL-BUILDING DEPT	4/08/21 APPROVED	TC
21 00001971	7232 SMITH FARM DR 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T	4/08/21 APPROVED	MP
21 00001972	8124 LONG TRAIL DR 37 00 POOL, BELOW/INGROUND	6010 0001 POOL STAKE OUT	4/08/21 APPROVED	TC
21 00002151	7525 REGAL LN 10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE RES COMM: Hole in panel	4/08/21 DISAPPROVED	MP
21 00002193	7517 REGAL LN 10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE	4/08/21 APPROVED	MP
21 00002255	7464 TIMBERHILL DR 37 00 POOL, BELOW/INGROUND	6020 0002 POOL BELLY STEEL/BONDING	4/08/21 APPROVED	TC
21 00002314	7513 REGAL LN 10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE RES COMM: Ground not connect, holes in panel	4/08/21 DISAPPROVED	MP
21 00002631	6417 PRECINCT LINE RD 28N 00 ELEC, NON DEFINEABLE AREA	2090 0001 ELEC FINAL	4/08/21 APPROVED	DJH
21 00002633	5616 JAMAICA CIR 84 00 MECH, RES-OUTDOOR AC/HT PUMP	4090 0002 MECH MECHANICAL FINAL	4/08/21 APPROVED	GT
21 00002646	6728 FAIR MEADOWS DR 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0002 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/08/21 APPROVED	TC
21 00002700	5009 SUSAN LEE LN 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0002 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection RES COMM: MISSING ATTIC ACCESS COVER IN GARAGE.	4/08/21 APPROVED WITH EXCEPT	TC
21 00002818	6606 CENTRAL AVE 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/08/21 APPROVED	TC

INSPECTION HISTORY REPORT
Wednesday, April 7, 2021

<u>APPLICATION</u>	<u>PROPERTY ADDRESS/PERMIT</u>	<u>INSPECTION</u>	<u>RESULT DATE/STATUS</u>	<u>INSPECTOR</u>
19 00002674	6492 IRON HORSE BLVD 12 00 BLDG, COMMERCIAL-NEW	1050 0001 BLDG SITE CONCRETE WORK RES COMM: Clean up trash. Sidewalk along garage #7 and #9	4/07/21 APPROVED WITH EXCEPT	DJH
19 00002675	6520 BROWNING DR 12 00 BLDG, COMMERCIAL-NEW	1017 0001 BLDG FIRE WALLS/ASSEMBLIE RES COMM: 3rd floor, unit shear wall screw pattern.	4/07/21 APPROVED	DJH
20 00001989	7100 RUFÉ SNOW DR 100 13 00 BLDG, COMMERCIAL RMDL/REPR	1014 0001 BLDG ELEC ROUGH-BURY/WALL RES COMM: Last inspection - Clean up all trash outside, this was not RES COMM: done, re-inspection fees due. Need mech permit.	4/07/21 DISAPPROVED WITH PEN	DJH
20 00003668	7937 SMITHFIELD RD 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS RES COMM: Walked house with owner first time builder. See tag in file RES COMM: and engineers letters on file.	4/07/21 DISAPPROVED	MP
20 00003993	8169 PRECINCT LINE RD 12 00 BLDG, COMMERCIAL-NEW	1005 0003 BLDG EXTERIOR SHEATHING	4/07/21 APPROVED	DJH
20 00004447	5665 TRAVELLER DR 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Need form board survey show house not in U.E. 4x3 bushing RES COMM: not a direction of flow fitting. Meter box damaged needs RES COMM: replace, set to grade and protected.	4/07/21 DISAPPROVED	MP
20 00004645	7364 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1005 0002 BLDG EXTERIOR SHEATHING	4/07/21 APPROVED	MP
20 00004774	8021 KANDY LN 37 00 POOL, BELOW/INGROUND	6080 0001 POOL PRE-PLASTER	4/07/21 APPROVED	TC
20 00004948	6904 COPPERHEAD TR 10 00 BLDG, SF-NEW	1090 0002 BLDG FINAL-BUILDING DEPT RES COMM: Lower ground rod. Caulk around tub. Clean out meter box. 4 RES COMM: to 1 max slope on N.elevation	4/07/21 APPROVED WITH EXCEPT	MP
20 00005077	5509 TRAVELLER DR 10 00 BLDG, SF-NEW	1017 0001 BLDG FIRE WALLS/ASSEMBLIE RES COMM: Int.firewall ok	4/07/21 APPROVED	MP
20 00005132	5660 TRAVELLER DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS	4/07/21 APPROVED	MP
20 00005191	5517 TRAVELLER DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION 1003 0002 BLDG TEMPORARY POLE	4/07/21 APPROVED 4/07/21 APPROVED	MP MP
21 00000100	8013 ODELL ST 10 00 BLDG, SF-NEW	1050 0001 BLDG SITE CONCRETE WORK	4/07/21 APPROVED	TC
21 00000341	7733 REIS LN 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS 1018 0001 BLDG INSULATION	4/07/21 APPROVED 4/07/21 APPROVED	MP MP
21 00000342	7737 REIS LN 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS 1018 0001 BLDG INSULATION	4/07/21 APPROVED 4/07/21 APPROVED	MP MP
21 00000343	5621 VALHALLA DR 37 00 POOL, BELOW/INGROUND	6080 0001 POOL PRE-PLASTER	4/07/21 APPROVED	TC
21 00000612	9220 ARMADILLO TR 10 00 BLDG, SF-NEW	1050 0001 BLDG SITE CONCRETE WORK	4/07/21 APPROVED	MP
21 00000631	7312 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1050 0001 BLDG SITE CONCRETE WORK	4/07/21 APPROVED	MP
21 00000800	9237 ARMADILLO TR 10 00 BLDG, SF-NEW	1050 0001 BLDG SITE CONCRETE WORK	4/07/21 APPROVED	MP
21 00000809	6800 SWITCHBACK TR 10 00 BLDG, SF-NEW	1050 0001 BLDG SITE CONCRETE WORK	4/07/21 APPROVED	MP
21 00001252	6817 CRANE RD 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE	4/07/21 APPROVED	DJH
21 00001260	8704 WOODBURY CT 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: No barrier up around tap. No trash bin or port a john on RES COMM: site. Set meter box to grade, backfill and protect from RES COMM: damages. Clean up loose trash on lot. No form board survey	4/07/21 DISAPPROVED	MP

	10 00 BLDG, SF-NEW		RES COMM: found in packet. Backfall on 3" in middle of house where RES COMM: marked. Water test low at 3" highest piping stand pipe. 1003 0001 BLDG TEMPORARY POLE RES COMM: No barrier up around tap. No trash bin or port a john on RES COMM: site. Set meter box to grade, backfill and protect from RES COMM: damages. Clean up loose trash on lot. No form board survey RES COMM: found in packet. Backfall on 3" in middle of house where RES COMM: marked. Water test low at 3" highest piping stand pipe.	4/07/21 DISAPPROVED	MP
21 00001285	8801 REDDING ST 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T		4/07/21 APPROVED	MP
21 00001329	8813 NORTH TARRANT PKWY 124 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0002 BLDG CERTIFICATE OF OCCY		4/07/21 APPROVED	DJH
21 00001370	6504 HARMONSON RD 11 00 BLDG, SF/MINOR REMODEL 50SF+	1015 0001 BLDG SECONDS RES COMM: need mechanical & electrical permits. no inspection made.		4/07/21 DISAPPROVED	TC
21 00001379	6904 COPPERHEAD TR 45 00 FENCE-CHAIN/WOOD/OTHER	1502 0001 FENCE FINAL		4/07/21 APPROVED	MP
21 00001425	8324 RED ROSE TR 11 00 BLDG, SF/MINOR REMODEL 50SF+	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: leave plns outside.		4/07/21 APPROVED WITH EXCEPT	TC
21 00001432	8528 DAVIS BLVD 150 13 00 BLDG, COMMERCIAL RMDL/REPR 13 00 BLDG, COMMERCIAL RMDL/REPR	1010 0001 BLDG FRAMING 1011 0001 BLDG PLUMBING TOP OUT		4/07/21 APPROVED 4/07/21 APPROVED	DJH DJH
21 00001579	4913 RUFÉ SNOW DR 102 13 00 BLDG, COMMERCIAL RMDL/REPR	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: Slab pour back at plbg.		4/07/21 APPROVED	DJH
21 00001787	8813 NORTH TARRANT PKWY 115 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0002 BLDG CERTIFICATE OF OCCY		4/07/21 APPROVED	DJH
21 00001937	6904 COPPERHEAD TR 32R 00 PLBG, RESIDENTIAL IRRIGATION	3003 0001 PLBG LAWN IRRIGATION		4/07/21 APPROVED	MP
21 00002072	7604 AUBREY LN 37 00 POOL, BELOW/INGROUND 37 00 POOL, BELOW/INGROUND	6025 0001 POOL UNDERGROUND ELECTRIC RES COMM: no permit 6040 0001 POOL PLUMBING/GAS/P TRAP RES COMM: no permit		4/07/21 DISAPPROVED 4/07/21 DISAPPROVED	TC TC
21 00002150	8408 EMERALD CIR 37 00 POOL, BELOW/INGROUND	6010 0001 POOL STAKE OUT		4/07/21 APPROVED	TC
21 00002384	6824 N STILLMEADOWS CIR 14 00 BLDG, SF FOUNDATION	1037 0003 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.		4/07/21 APPROVED	TC
21 00002393	5520 FINIAN LN 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0002 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection		4/07/21 APPROVED	GT
21 00002417	7029 HANGING CLIFF PL 14 00 BLDG, SF FOUNDATION	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.		4/07/21 APPROVED	TC
21 00002424	7229 YORK ST 11 00 BLDG, SF/MINOR REMODEL 50SF+ 11 00 BLDG, SF/MINOR REMODEL 50SF+ 43 00 PAVING SW/RES DW/DA	1001 0001 BLDG STRUCTURAL CONCRETE 1050 0001 BLDG SITE CONCRETE WORK 1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.		4/07/21 APPROVED 4/07/21 APPROVED 4/07/21 APPROVED	TC TC TC
21 00002454	6824 RIDGETOP RD 14 00 BLDG, SF FOUNDATION	1037 0002 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS. RES COMM: provide engineers final report letter at final.		4/07/21 DISAPPROVED	TC
21 00002582	5632 GUADALAJARA DR 14 00 BLDG, SF FOUNDATION	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.		4/07/21 APPROVED	TC
21 00002638	8315 THORNRIE DR				

	35 00 PLBG, MISCELLANEOUS	3090 0002 PLBG PLUMBING FINAL RES COMM: Photosare on their sidem I don't need closeuos, I need to RES COMM: see both bents, tops of units in one photo showing the RES COMM: plumbing in paralles and the water cut offs	4/07/21 DISAPPROVED	GT
21 00002723	8800 THORNBRIDGE DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/07/21 APPROVED	GT
21 00002736	6713 FAIR MEADOWS DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/07/21 APPROVED	GT
21 00002760	8128 BEVERLY DR 90 00 COURTESY INSPECTION-BLDG	90 0002 COURTESY INSPECTION-BLDG RES COMM: need plumbing permit	4/07/21 APPROVED WITH EXCEPT	GT
21 00002764	5708 CANCUN DR 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/07/21 APPROVED	TC
21 00002771	7128 SWEETBRIAR CT 18R 00 BLDG, RES RE-ROOF WITH DECKING	1030 0001 BLDG DECKING	4/07/21 APPROVED	GT
21 00002789	8401 PARKDALE DR A 90 00 COURTESY INSPECTION-BLDG	90 0001 COURTESY INSPECTION-BLDG RES COMM: need general permit with trades	4/07/21 APPROVED WITH EXCEPT	GT
21 00002796	5520 FINIAN LN 45 00 FENCE-CHAIN/WOOD/OTHER	1502 0001 FENCE FINAL	4/07/21 APPROVED	GT

INSPECTION HISTORY REPORT
Tuesday, April 6, 2021

APPLICATION	PROPERTY ADDRESS/PERMIT	INSPECTION	RESULT DATE/STATUS	INSPECTOR
16 00004555	6290 PEYTON WY 10 00 BLDG, SF-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA	4/06/21 APPROVED	MP
17 00001150	6278 PEYTON WY 10 00 BLDG, SF-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA	4/06/21 APPROVED	MP
17 00001175	6286 PEYTON WY 10 00 BLDG, SF-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA	4/06/21 APPROVED	MP
19 00002675	6520 BROWNING DR 12 00 BLDG, COMMERCIAL-NEW	1015 0002 BLDG SECONDS REQ COMM: Seal top plate and bottom plate as needed, seal dryer vent REQ COMM: chase as needed. RES COMM: Seal top and bottom plate as needed, and dryer vent chase as RES COMM: needed.	4/06/21 APPROVED WITH EXCEPT	DJH
19 00005726	8625 DAVIS BLVD 17 00 BLDG, MF-NEW	1005 0006 BLDG EXTERIOR SHEATHING RES COMM: section 6 and 7.	4/06/21 APPROVED	DJH
20 00001312	8609 DAVIS BLVD 16 00 BLDG, TRIPLEX/QUAD-NEW	1015 0001 BLDG SECONDS RES COMM: see punch list.	4/06/21 DISAPPROVED	DJH
20 00001313	8611 DAVIS BLVD 15 00 BLDG, DUPLEX UNITS-NEW	1041 0003 BLDG BRICK TIE INSPECTION	4/06/21 APPROVED	DJH
20 00001815	8001 NORTHEAST PKWY 12 00 BLDG, COMMERCIAL-NEW	1047 0001 BLDG TEMPORARY GAS RELEASES RES COMM: Paint the gas line move unions to the rtu side of the shut RES COMM: off valve.	4/06/21 APPROVED WITH EXCEPT	DJH
20 00003808	8313 SAYERS LN 10 00 BLDG, SF-NEW	1050 0002 BLDG SITE CONCRETE WORK RES COMM: F.U. with P.W. on approval. Also missing 1x4 set for gutter RES COMM: flow line. Missing expansion joints at slab	4/06/21 DISAPPROVED	MP
20 00003945	7308 EVERGLADE DR 45 00 FENCE-CHAIN/WOOD/OTHER	1502 0001 FENCE FINAL	4/06/21 APPROVED	TC
20 00003993	8169 PRECINCT LINE RD 12 00 BLDG, COMMERCIAL-NEW	1005 0002 BLDG EXTERIOR SHEATHING RES COMM: Add screws as needed.	4/06/21 DISAPPROVED	DJH
20 00004449	5653 TRAVELLER DR 10 00 BLDG, SF-NEW	1017 0002 BLDG FIRE WALLS/ASSEMBLIE RES COMM: Int. firewall ok	4/06/21 APPROVED	MP
20 00004645	7364 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1003 0003 BLDG TEMPORARY POLE	4/06/21 APPROVED	MP
20 00004950	8145 PRECINCT LINE RD 455 00 FENCE-SUBDV MASONRY SCR N WALL	1501 0001 FENCE MASONRY WALL FINAL	4/06/21 APPROVED	DJH
20 00005463	8536 FRESH MEADOWS RD 10 00 BLDG, SF-NEW	1005 0003 BLDG EXTERIOR SHEATHING RES COMM: Corrections made from previous inspections.	4/06/21 APPROVED	MP
21 00000049	6844 MEADOW CREST DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS RES COMM: cancel by inspector, too many workers on site working	4/06/21 CANCELLED	MP
21 00000052	6848 MEADOW CREST DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS RES COMM: See list in file	4/06/21 DISAPPROVED	MP
21 00000314	8309 SAYERS LN 10 00 BLDG, SF-NEW	1005 0002 BLDG EXTERIOR SHEATHING RES COMM: Requested 2nds.. need to pass sheathing first. Item #4 RES COMM: still not corrected per engineering, missing header straps RES COMM: and now headers are covered with hardie.	4/06/21 DISAPPROVED	MP
21 00000319	7721 REIS LN 10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION	4/06/21 APPROVED	MP
21 00000339	7725 REIS LN 10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION	4/06/21 APPROVED	MP
21 00000340	7729 REIS LN 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS 1018 0001 BLDG INSULATION	4/06/21 APPROVED 4/06/21 APPROVED	MP MP
21 00000454	9300 WESTERN RIDGE TR			

	10 00 BLDG, SF-NEW	1050 0001 BLDG SITE CONCRETE WORK RES COMM: Uncover meter box for inspections	4/06/21 APPROVED WITH EXCEPT	MP
21 00000632	7384 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1041 0001 BLDG BRICK TIE INSPECTION RES COMM: OK to brick and install siding.	4/06/21 APPROVED WITH EXCEPT	MP
21 00000701	6321 SUDBURY WY 285 00 ELEC, PHOTOVOLTAIC (SOLAR)	2015 0002 ELEC SERVICE UPGRADE	4/06/21 APPROVED	TC
21 00000809	6800 SWITCHBACK TR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS 1018 0001 BLDG INSULATION	4/06/21 APPROVED 4/06/21 APPROVED	MP MP
21 00000830	9308 WESTERN RIDGE TR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS 1018 0001 BLDG INSULATION	4/06/21 APPROVED 4/06/21 APPROVED	MP MP
21 00000920	9225 ARMADILLO TR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1050 0001 BLDG SITE CONCRETE WORK 1015 0002 BLDG SECONDS 1018 0001 BLDG INSULATION	4/06/21 APPROVED 4/06/21 APPROVED 4/06/21 APPROVED	MP MP MP
21 00001060	6717 MEADOW RD 10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE RES COMM: Secure loose trash and materials from blowing around.	4/06/21 APPROVED WITH EXCEPT	MP
21 00001122	8312 SAYERS LN 37 00 POOL, BELOW/INGROUND	6030 0001 POOL DECK STEEL & BONDING RES COMM: NOTE+++ this gate will not pass for pre-plaster inspection RES COMM: plan fo fencing requirements.	4/06/21 APPROVED WITH EXCEPT	MP
21 00001156	6800 SWALLOW LN 37 00 POOL, BELOW/INGROUND	6020 0003 POOL BELLY STEEL/BONDING RES COMM: need 4 ground clamps	4/06/21 DISAPPROVED	TC
21 00001284	7304 BOCA RATON DR 37 00 POOL, BELOW/INGROUND	6025 0001 POOL UNDERGROUND ELECTRIC	4/06/21 APPROVED	TC
21 00001307	8136 WOODS LN 10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE	4/06/21 APPROVED	MP
21 00001370	6504 HARMONSON RD 11 00 BLDG, SF/MINOR REMODEL 50SF+	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: ADD HANGERS EVERY 4 FT.	4/06/21 APPROVED WITH EXCEPT	TC
21 00001432	8528 DAVIS BLVD 150 13 00 BLDG, COMMERCIAL RMDL/REPR	1013 0001 BLDG MECHANICAL ROUGH RES COMM: Seal fittings at front lobby. The electrical permit has not RES COMM: been pulled.	4/06/21 APPROVED WITH EXCEPT	DJH
21 00001445	8813 NORTH TARRANT PKWY 117 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0002 BLDG CERTIFICATE OF OCCY	4/06/21 APPROVED	DJH
21 00001453	5121 RUFÉ SNOW DR 100 12A 00 BLDG, COMMERCIAL-ADDITION/TFO 12A 00 BLDG, COMMERCIAL-ADDITION/TFO 12A 00 BLDG, COMMERCIAL-ADDITION/TFO	1018 0003 BLDG INSULATION 1025 0001 BLDG CIELING COVER UP 1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: Health and fire dept inspections are 1st. Need to apply for RES COMM: a C.O.	4/06/21 APPROVED 4/06/21 APPROVED 4/06/21 DISAPPROVED	DJH DJH DJH
21 00001547	6521 TABOR ST 41 00 GARAGE/CARPORT/PERM ACCY BLDG	1001 0002 BLDG STRUCTURAL CONCRETE	4/06/21 APPROVED	TC
21 00001579	4913 RUFÉ SNOW DR 102 13 00 BLDG, COMMERCIAL RMDL/REPR	1014 0001 BLDG ELEC ROUGH-BURY/WALL	4/06/21 APPROVED	DJH
21 00001623	7680 RAMBLER LN 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T 1003 0001 BLDG TEMPORARY POLE	4/06/21 APPROVED 4/06/21 APPROVED	MP MP
21 00001624	7684 RAMBLER LN 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T 1003 0001 BLDG TEMPORARY POLE	4/06/21 APPROVED 4/06/21 APPROVED	MP MP
21 00001625	7688 RAMBLER LN 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T 1003 0001 BLDG TEMPORARY POLE	4/06/21 APPROVED 4/06/21 APPROVED	MP MP
21 00001654	6424 BUCKINGHAM TR WIND 00 BLDG, WINDOW REPLACEMENT>3	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/06/21 APPROVED	TC
21 00001793	6008 MAYBROOK DR 32R 00 PLBG, RESIDENTIAL IRRIGATION	3005 0001 PLBG PLUMBING ROUGH	4/06/21 APPROVED	MP

21 00001828	7016 RIDGE LINE DR 40A 00 BLDG, PERM ACCESSORY BUILDING	1010 0001 BLDG FRAMING	4/06/21 APPROVED	TC
21 00001965	4716 CATALINA CT 14 00 BLDG, SF FOUNDATION	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/06/21 APPROVED	TC
21 00001996	6004 MAYBROOK DR 32R 00 PLBG, RESIDENTIAL IRRIGATION	3005 0001 PLBG PLUMBING ROUGH	4/06/21 APPROVED	MP
21 00002077	6113 PARKER BLVD 32C 00 PLBG, COMMERCIAL IRRIGATION	3003 0001 PLBG LAWN IRRIGATION	4/06/21 APPROVED	MP
21 00002078	8481 EMERALD CIR 37 00 POOL, BELOW/INGROUND	6025 0001 POOL UNDERGROUND ELECTRIC	4/06/21 APPROVED	TC
21 00002194	8628 NICHOLS WY 35 00 PLBG, MISCELLANEOUS	3090 0002 PLBG PLUMBING FINAL RES COMM: Hard pipe gas	4/06/21 APPROVED WITH EXCEPT	MP
21 00002198	8801 RIDGE RUN DR 37 00 POOL, BELOW/INGROUND	6010 0001 POOL STAKE OUT	4/06/21 APPROVED	TC
21 00002229	7305 MARKET CT 47 00 RETAINING WALL	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: clean driveway & street. RES COMM: footing inspection.	4/06/21 APPROVED WITH EXCEPT	TC
21 00002255	7464 TIMBERHILL DR 37 00 POOL, BELOW/INGROUND 37 00 POOL, BELOW/INGROUND	6010 0001 POOL STAKE OUT 6020 0001 POOL BELLY STEEL/BONDING RES COMM: NO ELECTRICAL PERMIT, NO INSPECTION MADE.	4/06/21 APPROVED 4/06/21 DISAPPROVED	TC TC
21 00002267	6600 PARKVIEW DR 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0002 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection RES COMM: missing trim plate on elec outlet in garage	4/06/21 APPROVED WITH EXCEPT	TC
21 00002272	6704 FAIR MEADOWS DR 11 00 BLDG, SF/MINOR REMODEL 50SF+ 11 00 BLDG, SF/MINOR REMODEL 50SF+	1000 0001 BLDG ROUGH PLUMBING/GAS T 1015 0001 BLDG SECONDS	4/06/21 APPROVED 4/06/21 APPROVED	GT GT
21 00002276	5587 DAVIS BLVD 300 01C 00 C OF O-NEW OCCUPANT/NEW USE	1046 0001 BLDG TEMPORARY ELEC RELEA	4/06/21 APPROVED	DJH
21 00002315	8427 BOULEVARD 26 01C 00 C OF O-NEW OCCUPANT/NEW USE	1046 0001 BLDG TEMPORARY ELEC RELEA	4/06/21 APPROVED	DJH
21 00002493	7600 TERESA CT 85 00 MECH, RES-INDOOR COOLING SYS	4090 0001 MECH MECHANICAL FINAL	4/06/21 APPROVED	GT
21 00002495	8901 MYRANDA CT 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/06/21 APPROVED	GT
21 00002522	6515 SMITHFIELD RD A 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0001 BLDG CERTIFICATE OF OCCY	4/06/21 APPROVED	DJH
21 00002527	7712 SHADOW WOOD DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/06/21 APPROVED	GT
21 00002556	7317 CROSS KEYS CIR 14 00 BLDG, SF FOUNDATION	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/06/21 APPROVED	TC
21 00002566	3727 MATSON DR 24 00 ELEC, SERVICE CHANGE/ADD	2090 0001 ELEC FINAL	4/06/21 APPROVED	TC
21 00002571	3620 WENDELL DR 43 00 PAVING SW/RES DW/DA	1050 0001 BLDG SITE CONCRETE WORK	4/06/21 APPROVED	TC
21 00002591	7333 COVENTRY CIR 28 00 ELEC, RESIDENTIAL-RMDL/RPR	2015 0001 ELEC SERVICE UPGRADE	4/06/21 APPROVED	TC
21 00002638	8315 THORN RIDGE DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL RES COMM: photos of such poor quality i cant tell what is what	4/06/21 DISAPPROVED	GT
21 00002654	7613 HIGHTOWER DR 14 00 BLDG, SF FOUNDATION	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/06/21 APPROVED	TC

21 00002670	5755 CARLISLE CT 600 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0001 BLDG CERTIFICATE OF OCCY	4/06/21 APPROVED	DJH
21 00002679	7501 RIDGEWAY AVE 83 00 MECH, RES-WHOLE SYS. REPLACE	4090 0001 MECH MECHANICAL FINAL	4/06/21 APPROVED	GT
21 00002700	5009 SUSAN LEE LN 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection RES COMM: no lock box code	4/06/21 DISAPPROVED	GT
21 00002712	8320 THORNHAVEN CT 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/06/21 APPROVED	GT
21 00002713	6705 BRITTANY PARK CT 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL RES COMM: need photos of work	4/06/21 DISAPPROVED	GT
21 00002730	7236 COVENTRY CT 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	4/06/21 APPROVED	TC
21 00002753	4921 MARYANNA WY 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/06/21 APPROVED	GT
21 00002756	7450 NE LOOP 820 94 00 COURTESY INSPECTION-SITE	90 0001 COURTESY INSPECTION-BLDG REQ COMM: need a republic dumpster & a plumbing permit for tub replacements RES COMM: need a republic dumpster and a plumbing permit for tub replacements	4/06/21 APPROVED WITH EXCEPT	GT
21 00002757	7008 GREEN RIDGE TR 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/06/21 APPROVED	GT
21 00002758	4920 BLANEY AVE 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	4/06/21 APPROVED	GT
21 00002760	8128 BEVERLY DR 90 00 COURTESY INSPECTION-BLDG	90 0001 COURTESY INSPECTION-BLDG RES COMM: need on site inspection	4/06/21 DISAPPROVED	GT

INSPECTION HISTORY REPORT
Monday, April 5, 2021

<u>APPLICATION</u>	<u>PROPERTY ADDRESS/PERMIT</u>	<u>INSPECTION</u>	<u>RESULT DATE/STATUS</u>	<u>INSPECTOR</u>
17 00000927	6021 PARKER BLVD 17 00 BLDG, MF-NEW	1050 0004 BLDG SITE CONCRETE WORK RES COMM: By the pool footing for wall.	4/05/21 APPROVED	DJH
18 00002862	6004 MAYBROOK DR CC 00 CONTRACTOR CHANGE	1046 0001 BLDG TEMPORARY ELEC RELEA RES COMM: Missing blank covers on elec. Missing inter systems bonding RES COMM: bar.	4/05/21 APPROVED WITH EXCEPT	MP
	CC 00 CONTRACTOR CHANGE	1047 0001 BLDG TEMPORARY GAS RELEAS	4/05/21 APPROVED	MP
19 00002649	6496 IRON HORSE BLVD 17 00 BLDG, MF-NEW	1041 0001 BLDG BRICK TIE INSPECTION RES COMM: Lath inspection, garage #9, and building #1 west side. RES COMM: clean up trash.	4/05/21 APPROVED WITH EXCEPT	DJH
20 00002955	7624 REGAL LN 10 00 BLDG, SF-NEW	1090 0001 BLDG FINAL-BUILDING DEPT	4/05/21 DISAPPROVED	MP
20 00002957	7628 REGAL LN 10 00 BLDG, SF-NEW	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: See list in file	4/05/21 DISAPPROVED	MP
20 00002976	7636 REGAL LN 10 00 BLDG, SF-NEW	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: Missing weep holes above lintels. AC lines need UV and RES COMM: damage protection. Seal exp joint and at ac lines. Missing RES COMM: attic tent. Missing p-gravel at DC valve. Insulate ac RES COMM: primary drain 5' from unit. Need complinace statement with RES COMM: final grade and drainage survey.	4/05/21 DISAPPROVED	MP
20 00002980	7644 REGAL LN 10 00 BLDG, SF-NEW	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: Remove lids on meter boxes for inspections. (locking lids) RES COMM: Clean out DC box and add p-gravel. AC lines not properly RES COMM: insulated. No hot water. Missing lock out breaker on oven. RES COMM: No access to gas valve at cooktop.	4/05/21 DISAPPROVED (locking lids) not properly reaker on oven.	MP
20 00003808	8313 SAYERS LN 10 00 BLDG, SF-NEW	1047 0003 BLDG TEMPORARY GAS RELEAS	4/05/21 APPROVED	MP
20 00003814	7337 GLENVIEW DR 12 00 BLDG, COMMERCIAL-NEW	1090 0004 BLDG FINAL-BUILDING DEPT	4/05/21 APPROVED	DJH
20 00004478	7605 DAVIS BLVD 12 00 BLDG, COMMERCIAL-NEW	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: wrap all plbg in the slab 2 x the pipe size. Pick up trash.	4/05/21 APPROVED WITH EXCEPT	DJH
20 00004542	7020 RIDGE CREST DR 37 00 POOL, BELOW/INGROUND	6090 0001 POOL FINAL	4/05/21 APPROVED	TC
20 00004645	7364 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING RES COMM: Missing detail 1 by backdoor. Missing red t=ply circled on RES COMM: plans.	4/05/21 DISAPPROVED	MP
	10 00 BLDG, SF-NEW	1003 0002 BLDG TEMPORARY POLE RES COMM: Bond neutrals and grounds	4/05/21 DISAPPROVED	MP
20 00005077	5509 TRAVELLER DR 10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION RES COMM: Missing batt support at master shower. Clean up trash and RES COMM: install erosion control.	4/05/21 APPROVED WITH EXCEPT n up trash and	MP
20 00005080	5521 TRAVELLER DR 10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION RES COMM: Clean up trash on lots and install erosion control.	4/05/21 APPROVED WITH EXCEPT	MP
20 00005082	5513 TRAVELLER DR 10 00 BLDG, SF-NEW	1017 0001 BLDG FIRE WALLS/ASSEMBLIE RES COMM: Int.firewall- clean up trash on lots.	4/05/21 APPROVED WITH EXCEPT	MP
20 00005132	5660 TRAVELLER DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING 1015 0001 BLDG SECONDS RES COMM: Missing nails on garage seams. Leak on 1.5" vent for RES COMM: washing machine. Master shower pan not leverl and not full RES COMM: for inspections. Check lav in master for leav. 2x4 over RES COMM: bored for plbg in master. Exhaust duct between floors must RES COMM: be hard piped. Waer test low on 2nd floor. Clean up trash RES COMM: on lot and install trash bin. Insulate 1" water.	4/05/21 APPROVED 4/05/21 DISAPPROVED	MP MP
20 00005191	5517 TRAVELLER DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS RES COMM: Clean up trash on lots.	4/05/21 APPROVED WITH EXCEPT	MP

10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE RES COMM: Remove panel cover for inspections.	4/05/21 DISAPPROVED	MP
21 00000001 5121 RUFÉ SNOW DR 150 12A 00 BLDG, COMMERCIAL-ADDITION/TFO	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: See punch list.	4/05/21 DISAPPROVED	DJH
21 00000530 7616 REGAL LN 10 00 BLDG, SF-NEW	1003 0004 BLDG TEMPORARY POLE RES COMM: Remove panel cover for inspections. RES COMM: No packet found on site.	4/05/21 DISAPPROVED	MP
21 00000571 6801 SIMMONS RD 10 00 BLDG, SF-NEW	1018 0002 BLDG INSULATION	4/05/21 APPROVED	MP
21 00000633 7316 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: See list in file	4/05/21 DISAPPROVED	MP
21 00000760 6808 SWITCHBACK TR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING RES COMM: See engineers letter in file 1015 0001 BLDG SECONDS RES COMM: Finish fire soffits. Missing cut off on hose bib. Cross RES COMM: brace tripples in master.	4/05/21 APPROVED 4/05/21 APPROVED WITH EXCEPT	MP MP
21 00001400 8621 HIGHTOWER DR 37 00 POOL, BELOW/INGROUND	6025 0001 POOL UNDERGROUND ELECTRIC	4/05/21 APPROVED	TC
21 00001407 7348 HIDDEN OAKS DR 11 00 BLDG, SF/MINOR REMODEL 50SF+	1090 0002 BLDG FINAL-BUILDING DEPT	4/05/21 APPROVED	TC
21 00001503 7201 SMITH FARM DR 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING RES COMM: Still missing erosion control. Secure all HTT straps around RES COMM: huse.	4/05/21 APPROVED WITH EXCEPT	MP
21 00001619 8805 THORNDALE CT 37 00 POOL, BELOW/INGROUND	6010 0001 POOL STAKE OUT	4/05/21 APPROVED	TC
21 00001663 7608 REGAL LN 10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE	4/05/21 APPROVED	MP
21 00001827 8104 THORNWOOD DR 11 00 BLDG, SF/MINOR REMODEL 50SF+ 11 00 BLDG, SF/MINOR REMODEL 50SF+	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: NO PLUMBING PERMIT, NO INSPECTION MADE. 1001 0001 BLDG STRUCTURAL CONCRETE	4/05/21 DISAPPROVED 4/05/21 APPROVED	TC TC
21 00001875 6501 NE LOOP 820 82 00 MECH, REMODEL/REPAIR/REPLACE	4090 0003 MECH MECHANICAL FINAL RES COMM: Split unit southwest corner line insulation must be RES COMM: protected, paint is not allowed as protection.	4/05/21 DISAPPROVED	DJH
21 00001977 6608 DAVIS BLVD 43A 00 PAVING COMMERCIAL PRIVATE PROP	1050 0001 BLDG SITE CONCRETE WORK RES COMM: partail 240' pending public works engineering inspection.	4/05/21 APPROVED WITH EXCEPT	DJH
21 00001979 6000 WESSEX ST 37 00 POOL, BELOW/INGROUND	6020 0001 POOL BELLY STEEL/BONDING	4/05/21 APPROVED	TC
21 00002110 8709 MONTROSE DR 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: Piers- Need trash bin, port a john and trash bin. Still RES COMM: drilling at 10:30am provide engineers inspection letter or RES COMM: call back in. Also picked up form board survey.	4/05/21 DISAPPROVED	MP
21 00002200 7416 BELLA LN 37 00 POOL, BELOW/INGROUND	6010 0001 POOL STAKE OUT	4/05/21 APPROVED	TC
21 00002235 5672 JAMAICA CIR 14 00 BLDG, SF FOUNDATION	1037 0002 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	4/05/21 APPROVED	TC
21 00002268 7337 GLENVIEW DR 54 00 SIGN, WALL	7003 0001 SIGN FINAL	4/05/21 APPROVED	DJH
21 00002384 6824 N STILLMEADOWS CIR 14 00 BLDG, SF FOUNDATION	1037 0002 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS. RES COMM: provide engineer final report letter for foundation final	4/05/21 DISAPPROVED	TC
21 00002447 4100 RUFÉ SNOW DR A 54 00 SIGN, WALL	7003 0001 SIGN FINAL	4/05/21 APPROVED	DJH

21 00002481	7337 GLENVIEW DR 01A 00 C OF O - NEW/ADDITION/INI TFO	1095 0001 BLDG CERTIFICATE OF OCCY	4/05/21 APPROVED	DJH
21 00002502	7109 TIMBERLANE DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL RES COMM: NO ENTRY.RECALL INSPECTION.	4/05/21 DISAPPROVED	TC
21 00002645	6720 DAVIS BLVD ATT 24 00 ELEC, SERVICE CHANGE/ADD	2090 0001 ELEC FINAL	4/05/21 APPROVED	DJH
21 00002646	6728 FAIR MEADOWS DR 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection RES COMM: missing smoke detector in middle bedroom. RES COMM: trim limbs away from roof.	4/05/21 DISAPPROVED	TC
21 00002664	7513 SUSAN CT 35 00 PLBG, MISCELLANEOUS 35 00 PLBG, MISCELLANEOUS	3005 0001 PLBG PLUMBING ROUGH 3090 0001 PLBG PLUMBING FINAL	4/05/21 APPROVED 4/05/21 APPROVED	TC TC
21 00002678	7912 HEATHERBROOK DR 32 00 PLBG, BACKFLOW DEV/IRRIGATION	3003 0001 PLBG LAWN IRRIGATION	4/05/21 APPROVED	TC
21 00002692	5716 STONE DR 35 00 PLBG, MISCELLANEOUS 35 00 PLBG, MISCELLANEOUS	3005 0001 PLBG PLUMBING ROUGH 3090 0001 PLBG PLUMBING FINAL	4/05/21 APPROVED 4/05/21 APPROVED	TC TC

INSPECTION HISTORY REPORT
Thursday, April 1, 2021

APPLICATION	PROPERTY ADDRESS/PERMIT	INSPECTION	RESULT DATE/STATUS	INSPECTOR
19 00002670	6494 IRON HORSE BLVD 12 00 BLDG, COMMERCIAL-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA RES COMM: 79 METERS.	4/01/21 APPROVED	DJH
19 00002675	6520 BROWNING DR 12 00 BLDG, COMMERCIAL-NEW	1018 0002 BLDG INSULATION RES COMM: 2ND FLOOR SECTION B - REPAIR DYER VENT CHASE AS NEEDED.	4/01/21 APPROVED WITH EXCEPT	DJH
19 00005596	8701 NORTH TARRANT PKWY 12 00 BLDG, COMMERCIAL-NEW	1046 0003 BLDG TEMPORARY ELEC RELEA	4/01/21 APPROVED	DJH
19 00005726	8625 DAVIS BLVD 17 00 BLDG, MF-NEW	1005 0005 BLDG EXTERIOR SHEATHING RES COMM: SECTION 2,& 6.	4/01/21 APPROVED	DJH
20 00001312	8609 DAVIS BLVD 16 00 BLDG, TRIPLEX/QUAD-NEW	1041 0002 BLDG BRICK TIE INSPECTION RES COMM: HOUSE WRAP IS DAMAGED. FEES DUE.	4/01/21 DISAPPROVED WITH PEN	DJH
20 00001313	8611 DAVIS BLVD 15 00 BLDG, DUPLEX UNITS-NEW	1041 0002 BLDG BRICK TIE INSPECTION RES COMM: HOUSE WRAP IS DAMAGED, WINDOW FLASHING MISSING. FEES DUE.	4/01/21 DISAPPROVED WITH PEN	DJH
20 00001315	8613 DAVIS BLVD 15 00 BLDG, DUPLEX UNITS-NEW	1041 0002 BLDG BRICK TIE INSPECTION RES COMM: HOUSE WRAP SHORT SOUTH SIDE.	4/01/21 APPROVED WITH EXCEPT	DJH
20 00001815	8001 NORTHEAST PKWY 12 00 BLDG, COMMERCIAL-NEW 12 00 BLDG, COMMERCIAL-NEW	1050 0012 BLDG SITE CONCRETE WORK RES COMM: 8 LIGHT POLE BASE PIERS, EAST LOT. 1025 0002 BLDG CIELING COVER UP RES COMM: AREA B RADIUS.	4/01/21 APPROVED 4/01/21 APPROVED	DJH DJH
20 00003808	8313 SAYERS LN 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1046 0003 BLDG TEMPORARY ELEC RELEA 1047 0002 BLDG TEMPORARY GAS RELEAS RES COMM: NO PRESSURE ON GAS TEST.	4/01/21 APPROVED 4/01/21 DISAPPROVED	TC TC
20 00003878	9113 CORDERO DR 10 00 BLDG, SF-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA	4/01/21 APPROVED	TC
20 00004043	6568 IRON HORSE BLVD 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1046 0002 BLDG TEMPORARY ELEC RELEA RES COMM: GROUND WIRE SPLICE- CLEAN AND WELD THE SPLICE. 1047 0001 BLDG TEMPORARY GAS RELEAS RES COMM: TEST GAUGE IS BEKOW 3LB TEST.	4/01/21 DISAPPROVED 4/01/21 DISAPPROVED	DJH DJH
20 00005077	5509 TRAVELLER DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS	4/01/21 APPROVED	DJH
20 00005080	5521 TRAVELLER DR 10 00 BLDG, SF-NEW	1015 0002 BLDG SECONDS	4/01/21 APPROVED	DJH
20 00005137	6801 SWITCHBACK TR 10 00 BLDG, SF-NEW	0000 0002 MISC INSPECTOR'S CHOICE RES COMM: MASTER TUB.	4/01/21 APPROVED	TC
21 00000454	9300 WESTERN RIDGE TR 10 00 BLDG, SF-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA	4/01/21 APPROVED	TC
21 00000529	7620 REGAL LN 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING RES COMM: EXTERIOR SHEATHING ONLY. INTERIOR SHEATHING HOLD DOWNS NOT RES COMM: DOWNS NOT SET.	4/01/21 APPROVED	DJH
21 00000530	7616 REGAL LN 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING	4/01/21 APPROVED	DJH
21 00000612	9220 ARMADILLO TR 10 00 BLDG, SF-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA	4/01/21 APPROVED	TC
21 00000910	6500 BOLD RULER LN 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1000 0002 BLDG ROUGH PLUMBING/GAS T 1003 0001 BLDG TEMPORARY POLE	4/01/21 APPROVED 4/01/21 APPROVED	TC TC
21 00000914	6508 BOLD RULER LN 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1000 0002 BLDG ROUGH PLUMBING/GAS T 1000 0003 BLDG ROUGH PLUMBING/GAS T	4/01/21 APPROVED 4/01/21 APPROVED	TC TC
21 00000918	6504 BOLD RULER LN 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1000 0002 BLDG ROUGH PLUMBING/GAS T 1003 0001 BLDG TEMPORARY POLE	4/01/21 APPROVED 4/01/21 APPROVED	TC TC
21 00000960	8120 SHADOW WOOD DR			

	37 00 POOL, BELOW/INGROUND	6025 0001 POOL UNDERGROUND ELECTRIC	4/01/21 APPROVED	TC
21 00000980	9121 MEANDERING DR 37 00 POOL, BELOW/INGROUND	6025 0001 POOL UNDERGROUND ELECTRIC	4/01/21 APPROVED	TC
21 00001170	5036 RUFÉ SNOW DR 12 00 BLDG, COMMERCIAL-NEW	1003 0001 BLDG TEMPORARY POLE	4/01/21 APPROVED	DJH
21 00001285	8801 REDDING ST 10 00 BLDG, SF-NEW	1003 0002 BLDG TEMPORARY POLE	4/01/21 APPROVED	DJH
21 00001329	8813 NORTH TARRANT PKWY 124 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0001 BLDG CERTIFICATE OF OCCY RES COMM: NOT READY.	4/01/21 DISAPPROVED	DJH
21 00001382	5524 GREENVIEW CT 37 00 POOL, BELOW/INGROUND	6025 0001 POOL UNDERGROUND ELECTRIC	4/01/21 APPROVED	GT
21 00001383	8813 NORTH TARRANT PKWY 137 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0001 BLDG CERTIFICATE OF OCCY	4/01/21 APPROVED	DJH
21 00001424	8813 NORTH TARRANT PKWY 127 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0001 BLDG CERTIFICATE OF OCCY	4/01/21 APPROVED	DJH
21 00001445	8813 NORTH TARRANT PKWY 117 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0001 BLDG CERTIFICATE OF OCCY RES COMM: NEED APPT. BOOK ON SITE.	4/01/21 DISAPPROVED	DJH
21 00001471	8601 MID CITIES BLVD 12 00 BLDG, COMMERCIAL-NEW	1001 0002 BLDG STRUCTURAL CONCRETE RES COMM: REPAIR VAPOR BARRIER, LIFT BOTTOM BEAM STEEL 2" CLEARANCE. RES COMM: NOTE NO UFER.	4/01/21 APPROVED WITH EXCEPT	DJH
21 00001481	8117 JERRIE JO DR 45 00 FENCE-CHAIN/WOOD/OTHER	1502 0001 FENCE FINAL	4/01/21 APPROVED	TC
21 00001787	8813 NORTH TARRANT PKWY 115 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0001 BLDG CERTIFICATE OF OCCY RES COMM: NOT READY.	4/01/21 DISAPPROVED	DJH
21 00001945	7917 LAZY LANE RD 43 00 PAVING SW/RES DW/DA	1090 0001 BLDG FINAL-BUILDING DEPT	4/01/21 APPROVED	TC
21 00002048	8520 FRESH MEADOWS RD 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: PIERS.	4/01/21 PARTIALLY APPROVED	TC
21 00002237	4321 ASHMORE DR 83 00 MECH, RES-WHOLE SYS. REPLACE	4090 0002 MECH MECHANICAL FINAL RES COMM: NO ENTRY. RES COMM: NO LOCK BOX FOUND	4/01/21 DISAPPROVED	TC
21 00002269	8620 GLENMONT DR 43A 00 PAVING COMMERCIAL PRIVATE PROP	1050 0001 BLDG SITE CONCRETE WORK	4/01/21 APPROVED	GT
21 00002368	7901 FOREST HILLS CT 47 00 RETAINING WALL	1001 0002 BLDG STRUCTURAL CONCRETE	4/01/21 APPROVED	GT
21 00002475	8554 KENSINGTON CT 14 00 BLDG, SF FOUNDATION	1001 0001 BLDG STRUCTURAL CONCRETE	4/01/21 APPROVED	GT
21 00002479	9004 BELSHIRE DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL RES COMM: need drip legs installed	4/01/21 DISAPPROVED	GT
21 00002488	8813 NORTH TARRANT PKWY 118 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0001 BLDG CERTIFICATE OF OCCY	4/01/21 APPROVED	DJH
21 00002501	5340 RUFÉ SNOW DR 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0001 BLDG CERTIFICATE OF OCCY	4/01/21 APPROVED	DJH
21 00002509	7121 ROMFORD WY 14 00 BLDG, SF FOUNDATION	1001 0001 BLDG STRUCTURAL CONCRETE	4/01/21 APPROVED	GT
21 00002577	7956 DAVIS BLVD 82 00 MECH, REMODEL/REPAIR/REPLACE	4090 0002 MECH MECHANICAL FINAL	4/01/21 APPROVED	GT
21 00002581	3916 DIAMOND LOCH W 14 00 BLDG, SF FOUNDATION	1001 0001 BLDG STRUCTURAL CONCRETE	4/01/21 APPROVED	GT
21 00002596	7208 WINDCREST CT E 24 00 ELEC, SERVICE CHANGE/ADD	2090 0001 ELEC FINAL	4/01/21 APPROVED	GT
21 00002619	5213 DAVIS BLVD H 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0001 BLDG CERTIFICATE OF OCCY RES COMM: NEED FIRE DEPT. INSPECTION 1ST.	4/01/21 DISAPPROVED	DJH
	01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0002 BLDG CERTIFICATE OF OCCY	4/01/21 APPROVED	GT
	01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0003 BLDG CERTIFICATE OF OCCY	4/01/21 APPROVED	GT

21 00002660 8325 JERRIE JO DR

24 00 ELEC, SERVICE CHANGE/ADD

2090 0001 ELEC FINAL

4/01/21 APPROVED

TC

INSPECTION HISTORY REPORT
Wednesday, March 31, 2021

APPLICATION	PROPERTY ADDRESS/PERMIT	INSPECTION	RESULT DATE/STATUS	INSPECTOR
20 00003136	7229 GREEN MEADOW DR 43 00 PAVING SW/RES DW/DA	1090 0001 BLDG FINAL-BUILDING DEPT	3/31/21 APPROVED	TC
20 00003808	8313 SAYERS LN 10 00 BLDG, SF-NEW	1046 0002 BLDG TEMPORARY ELEC RELEA RES COMM: Temp power letter not completed. Fill out type of release, RES COMM: owner info, phone number, initials.	3/31/21 DISAPPROVED	MP
20 00003993	8169 PRECINCT LINE RD 12 00 BLDG, COMMERCIAL-NEW	1005 0001 BLDG EXTERIOR SHEATHING RES COMM: Not ready, add screws, inspection stop.	3/31/21 DISAPPROVED	DJH
20 00004449	5653 TRAVELLER DR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1015 0004 BLDG SECONDS 1018 0001 BLDG INSULATION	3/31/21 APPROVED 3/31/21 APPROVED	MP MP
20 00004645	7364 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE RES COMM: No elec permit , no inspections. Day 2 for same RES COMM: elec.contractor. Fee due.	3/31/21 DISAPPROVED WITH PEN	MP
20 00005070	6305 ROVER LN 10 00 BLDG, SF-NEW	1090 0004 BLDG FINAL-BUILDING DEPT RES COMM: 1st run step is a little off of minimum10" wide, follow up RES COMM: with builder. Ok to move in.	3/31/21 APPROVED WITH EXCEPT	MP
20 00005191	5517 TRAVELLER DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: See completed punch list in file. Inspections completed for RES COMM: work completed.	3/31/21 DISAPPROVED	MP
20 00005463	8536 FRESH MEADOWS RD 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1005 0002 BLDG EXTERIOR SHEATHING RES COMM: MISSING BRICK TIES. 1015 0002 BLDG SECONDS RES COMM: SHOWER PAN NOT READY. RES COMM: MISSING FRONT DOOR & WINDOW.	3/31/21 DISAPPROVED 3/31/21 DISAPPROVED	TC TC
21 00000001	5121 RUFÉ SNOW DR 150 12A 00 BLDG, COMMERCIAL-ADDITION/TFO	1025 0003 BLDG CIELING COVER UP RES COMM: Outlets above the ceiling grid not allowed. PLBG line RES COMM: hangers loose.	3/31/21 APPROVED WITH EXCEPT	DJH
21 00000190	8217 RIO VISTA CT 37 00 POOL, BELOW/INGROUND	6090 0001 POOL FINAL	3/31/21 APPROVED	TC
21 00000319	7721 REIS LN 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1041 0001 BLDG BRICK TIE INSPECTION 1015 0001 BLDG SECONDS RES COMM: Nail plate kitchen. Backfall pan line in garage.	3/31/21 APPROVED 3/31/21 APPROVED WITH EXCEPT	MP MP
21 00000339	7725 REIS LN 10 00 BLDG, SF-NEW	1041 0001 BLDG BRICK TIE INSPECTION	3/31/21 APPROVED	MP
21 00000340	7729 REIS LN 10 00 BLDG, SF-NEW	1041 0001 BLDG BRICK TIE INSPECTION	3/31/21 APPROVED	MP
21 00000341	7733 REIS LN 10 00 BLDG, SF-NEW	1041 0001 BLDG BRICK TIE INSPECTION	3/31/21 APPROVED	MP
21 00000342	7737 REIS LN 10 00 BLDG, SF-NEW	1041 0001 BLDG BRICK TIE INSPECTION	3/31/21 APPROVED	MP
21 00000571	6801 SIMMONS RD 10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION RES COMM: Corrections not made from previous 2nds tag, see tag.	3/31/21 DISAPPROVED	MP
21 00000632	7384 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1005 0002 BLDG EXTERIOR SHEATHING RES COMM: Missing HTT on rear and finish 2nd floor staples.	3/31/21 APPROVED WITH EXCEPT	MP
21 00001453	5121 RUFÉ SNOW DR 100 12A 00 BLDG, COMMERCIAL-ADDITION/TFO 12A 00 BLDG, COMMERCIAL-ADDITION/TFO	1014 0002 BLDG ELEC ROUGH-BURY/WALL RES COMM: Sign permit required, exterior conduit ok. Relocate conduit RES COMM: in empty suite. 1050 0001 BLDG SITE CONCRETE WORK RES COMM: Sign permit required, piers ok.	3/31/21 PARTIALLY APPROVED 3/31/21 APPROVED WITH EXCEPT	DJH DJH
21 00001571	6344 DAVIS BLVD 01B 00 C OF O-CHANGE NAME/OWNER/REMOD	1095 0001 BLDG CERTIFICATE OF OCCY	3/31/21 APPROVED	DJH
21 00001572	6344 DAVIS BLVD 200 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0001 BLDG CERTIFICATE OF OCCY	3/31/21 APPROVED	DJH

21 00001662	7612 REGAL LN 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Set meter box and backfill	3/31/21 APPROVED WITH EXCEPT	MP
21 00001663	7608 REGAL LN 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: No elec permit on file and tpole installed. Set meter box RES COMM: to grade and backfill	3/31/21 APPROVED WITH EXCEPT	MP
21 00001728	7621 JEAN ANN DR 28S 00 ELEC, PHOTOVOLTAIC (SOLAR)	2015 0001 ELEC SERVICE UPGRADE RES COMM: PROVIDE 2 MEANS OF GROUNDING.	3/31/21 DISAPPROVED	TC
21 00001860	7628 FORD DR WIND 00 BLDG, WINDOW REPLACEMENT>3	1090 0001 BLDG FINAL-BUILDING DEPT	3/31/21 APPROVED	DJH
21 00001945	7917 LAZY LANE RD 43 00 PAVING SW/RES DW/DA	1050 0003 BLDG SITE CONCRETE WORK RES COMM: Add gutter flow line agaisnt curb .75 to 1" max high. Call RES COMM: for final once completed and poured.	3/31/21 APPROVED WITH EXCEPT	MP
21 00002079	4100 MACKEY DR 28S 00 ELEC, PHOTOVOLTAIC (SOLAR)	2015 0001 ELEC SERVICE UPGRADE RES COMM: PROVIDE 2 MEANS OF GROUNDING.	3/31/21 DISAPPROVED	TC
21 00002129	6740 GREENACRES DR 14 00 BLDG, SF FOUNDATION	1037 0002 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	3/31/21 APPROVED	TC
21 00002156	7637 KIMBERLY CT 32R 00 PLBG, RESIDENTIAL IRRIGATION	3003 0001 PLBG LAWN IRRIGATION RES COMM: MAILED BACKFLOW TEST REPORT TO CITY.	3/31/21 APPROVED	TC
21 00002219	5404 TOPPER DR 83 00 MECH, RES-WHOLE SYS. REPLACE	4090 0001 MECH MECHANICAL FINAL	3/31/21 APPROVED	GT
21 00002236	8809 KIRK LN 24 00 ELEC, SERVICE CHANGE/ADD	2090 0001 ELEC FINAL	3/31/21 APPROVED	DJH
21 00002249	7344 MAPLE DR 43 00 PAVING SW/RES DW/DA	1050 0001 BLDG SITE CONCRETE WORK	3/31/21 APPROVED	TC
21 00002335	5513 FINIAN LN 18R 00 BLDG, RES RE-ROOF WITH DECKING	1037 0002 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	3/31/21 APPROVED	TC
21 00002374	6840 MEADOW CREST DR 72R 00 FIRE SPRINKLER RESIDENTIAL SYS	5040 0001 FIRE SPRINKLER AIR/HYDRO	3/31/21 APPROVED	MP
21 00002375	6844 MEADOW CREST DR 72R 00 FIRE SPRINKLER RESIDENTIAL SYS	5040 0001 FIRE SPRINKLER AIR/HYDRO	3/31/21 APPROVED	MP
21 00002376	6848 MEADOW CREST DR 72R 00 FIRE SPRINKLER RESIDENTIAL SYS	5040 0001 FIRE SPRINKLER AIR/HYDRO	3/31/21 APPROVED	MP
21 00002377	6852 MEADOW CREST DR 72R 00 FIRE SPRINKLER RESIDENTIAL SYS	5040 0001 FIRE SPRINKLER AIR/HYDRO	3/31/21 APPROVED	MP
21 00002378	6856 MEADOW CREST DR 72R 00 FIRE SPRINKLER RESIDENTIAL SYS	5040 0001 FIRE SPRINKLER AIR/HYDRO	3/31/21 APPROVED	MP
21 00002448	8609 HIGHTOWER DR 24 00 ELEC, SERVICE CHANGE/ADD	2090 0001 ELEC FINAL	3/31/21 APPROVED	TC
21 00002455	5105 GIBBONS DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	3/31/21 APPROVED	TC
21 00002567	7228 TIMBERIDGE DR 43 00 PAVING SW/RES DW/DA	1050 0001 BLDG SITE CONCRETE WORK	3/31/21 APPROVED	TC
21 00002577	7956 DAVIS BLVD 82 00 MECH, REMODEL/REPAIR/REPLACE	4090 0001 MECH MECHANICAL FINAL RES COMM: Attic unit support the gas line.	3/31/21 DISAPPROVED	DJH
21 00002607	7901 MID CITIES BLVD 212 23 00 ELEC, TEMPORARY SERVICE	2030 0002 ELEC TEMP ELEC/CLEAN & SH	3/31/21 APPROVED	DJH
21 00002628	5587 DAVIS BLVD 01B 00 C OF O-CHANGE NAME/OWNER/REMOD	1095 0001 BLDG CERTIFICATE OF OCCY RES COMM: Loose electric wires at exterior front of suite #500. RES COMM: Shower installed without permit in #300 must be removed.	3/31/21 DISAPPROVED	DJH
21 00002632	7532 CIRCLE DR 84 00 MECH, RES-OUTDOOR AC/HT PUMP	4090 0001 MECH MECHANICAL FINAL	3/31/21 APPROVED	GT

21 00002633

5616 JAMAICA CIR

84 00 MECH, RES-OUTDOOR AC/HT PUMP

4090 0001 MECH MECHANICAL FINAL

RES COMM: need a water diverter on the roof above the unit.

3/31/21 DISAPPROVED

GT

INSPECTION HISTORY REPORT
Tuesday, March 30, 2021

<u>APPLICATION</u>	<u>PROPERTY ADDRESS/PERMIT</u>	<u>INSPECTION</u>	<u>RESULT DATE/STATUS</u>	<u>INSPECTOR</u>
17 00000930	6040 ASHBURY ST 17 00 BLDG, MF-NEW	1090 0002 BLDG FINAL-BUILDING DEPT RES COMM: 1st floor unit punch list.	3/30/21 DISAPPROVED	DJH
19 00002649	6496 IRON HORSE BLVD 17 00 BLDG, MF-NEW	1037 0002 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS. RES COMM: Lath southside.	3/30/21 APPROVED	DJH
19 00002675	6520 BROWNING DR 12 00 BLDG, COMMERCIAL-NEW	1018 0001 BLDG INSULATION RES COMM: Wall insulation 3rd floor units section B.	3/30/21 PARTIALLY APPROVED	DJH
19 00005596	8701 NORTH TARRANT PKWY 12 00 BLDG, COMMERCIAL-NEW 12 00 BLDG, COMMERCIAL-NEW	1046 0001 BLDG TEMPORARY ELEC RELEA RES COMM: Nee two means of ground. 1046 0002 BLDG TEMPORARY ELEC RELEA RES COMM: Need two means of ground. Color code the ground and neutral RES COMM: wires.	3/30/21 DISAPPROVED 3/30/21 DISAPPROVED	DJH DJH
20 00001312	8609 DAVIS BLVD 16 00 BLDG, TRIPLEX/QUAD-NEW	1041 0001 BLDG BRICK TIE INSPECTION RES COMM: Bond barrier missing, start ties.	3/30/21 DISAPPROVED	DJH
20 00001313	8611 DAVIS BLVD 15 00 BLDG, DUPLEX UNITS-NEW	1041 0001 BLDG BRICK TIE INSPECTION RES COMM: Bond barrier missing at ledge. Window flashing missing. RES COMM: Damaged wrap.	3/30/21 DISAPPROVED ing missing.	DJH
20 00001315	8613 DAVIS BLVD 15 00 BLDG, DUPLEX UNITS-NEW	1041 0001 BLDG BRICK TIE INSPECTION RES COMM: Bond barrier missing, start ties with in 12" of the ledge.	3/30/21 DISAPPROVED " of the ledge.	DJH
20 00001815	8001 NORTHEAST PKWY 12 00 BLDG, COMMERCIAL-NEW	1050 0011 BLDG SITE CONCRETE WORK RES COMM: northside of C 12' walkway 165', and 4' walkway 135'	3/30/21 APPROVED	DJH
20 00004039	6572 IRON HORSE BLVD 10 00 BLDG, SF-NEW	1050 0002 BLDG SITE CONCRETE WORK RES COMM: driveway	3/30/21 APPROVED	MP
20 00004040	6576 IRON HORSE BLVD 10 00 BLDG, SF-NEW	1050 0002 BLDG SITE CONCRETE WORK RES COMM: driveway	3/30/21 APPROVED	MP
20 00004041	6580 IRON HORSE BLVD 10 00 BLDG, SF-NEW	1050 0002 BLDG SITE CONCRETE WORK RES COMM: driveway	3/30/21 APPROVED	MP
20 00004042	6584 IRON HORSE BLVD 10 00 BLDG, SF-NEW	1050 0002 BLDG SITE CONCRETE WORK RES COMM: driveway	3/30/21 APPROVED	MP
20 00004043	6568 IRON HORSE BLVD 10 00 BLDG, SF-NEW	1050 0002 BLDG SITE CONCRETE WORK RES COMM: driveway	3/30/21 APPROVED	MP
20 00004449	5653 TRAVELLER DR 10 00 BLDG, SF-NEW	1015 0003 BLDG SECONDS RES COMM: Need to pass 2nd before insulation approval. Corrections RES COMM: not made, no waer test on plbg and missing hurricane straps RES COMM: above entry.	3/30/21 DISAPPROVED . Corrections	MP
20 00004451	5661 TRAVELLER DR 10 00 BLDG, SF-NEW	1017 0002 BLDG FIRE WALLS/ASSEMBLIE RES COMM: Int. firewall ok	3/30/21 APPROVED	MP
20 00005070	6305 ROVER LN 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1090 0002 BLDG FINAL-BUILDING DEPT RES COMM: Corrections not made. Leak under kitchen sink. AC must be RES COMM: 3" above grade. Threshold loose at door to garage. RES COMM: NOTE... open permit for builder sign and not complete. RES COMM: Missing ADA parking sign. 1090 0003 BLDG FINAL-BUILDING DEPT RES COMM: Corrections not made. Leak under kitchen sink. Steps in RES COMM: garage have been replace but now do not meet minimum 10" RES COMM: tread depth	3/30/21 DISAPPROVED WITH PEN 3/30/21 DISAPPROVED WITH PEN	MP MP
20 00005077	5509 TRAVELLER DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: No test on PVC. Master lav outlet must be 3' away from	3/30/21 DISAPPROVED	MP

RES COMM: waters edge at shower. Missing nail plates on kitchen.
 RES COMM: Support valley above kitchen. Missing collar tie above
 RES COMM: kitchen and living room.

20 00005080	5521 TRAVELLER DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: Missing hurricane straps above entry. Support upper ends of RES COMM: valleys over kitchen. Nail plate master commode vent. RES COMM: Missing nails on interior braced walls.	3/30/21 DISAPPROVED	MP
20 00005082	5513 TRAVELLER DR 10 00 BLDG, SF-NEW	1018 0001 BLDG INSULATION	3/30/21 APPROVED	MP
20 00005191	5517 TRAVELLER DR 10 00 BLDG, SF-NEW	1005 0002 BLDG EXTERIOR SHEATHING	3/30/21 APPROVED	MP
21 00000049	6844 MEADOW CREST DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: No inspections need to clean up subdivision	3/30/21 DISAPPROVED	MP
21 00000052	6848 MEADOW CREST DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: no inspections need to clean up subdivision	3/30/21 DISAPPROVED	MP
21 00000057	6840 MEADOW CREST DR 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: no inspections need to clean up subdivision	3/30/21 DISAPPROVED	MP
21 00000339	7725 REIS LN 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: Poly seal penetrations to outside above the garage door. RES COMM: Missing hanger on ceiling joist above master. Hle in roof, RES COMM: not dry in.	3/30/21 APPROVED WITH EXCEPT	MP
21 00000340	7729 REIS LN 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: Finish framing on chase by fridge. Seal penetrations thru RES COMM: exterior above garage. Dry in roof. Secure pex every 32" RES COMM: Seal chases in master closet. Backfall on vent in master RES COMM: bath chase.	3/30/21 DISAPPROVED	MP
21 00000341	7733 REIS LN 10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: Fireblock missing at stairs. Dry in roof. Secure ac boot in RES COMM: master and dryer vent. Draft stop chase 2nd floor.	3/30/21 DISAPPROVED	MP
21 00000632	7384 PARKSIDE PLACE DR 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING RES COMM: No inspections, electric work done without permits subject RES COMM: to 525.00 violation fee	3/30/21 DISAPPROVED	MP
21 00000742	6425 NORTHERN DANCER DR 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING RES COMM: All units 6425-6441 Fire walls and patios not ready. OK to RES COMM: tape and install brick ties.	3/30/21 DISAPPROVED	MP
21 00000809	6800 SWITCHBACK TR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1005 0002 BLDG EXTERIOR SHEATHING RES COMM: See 2nds. 1015 0001 BLDG SECONDS RES COMM: No test on plbg. Poly seal holes in exterior. Missing INT. RES COMM: braced wall anchors. Need engineers letter for windbracing	3/30/21 APPROVED WITH EXCEPT 3/30/21 DISAPPROVED	MP MP
21 00000830	9308 WESTERN RIDGE TR 10 00 BLDG, SF-NEW 10 00 BLDG, SF-NEW	1005 0001 BLDG EXTERIOR SHEATHING RES COMM: See 2nds 1015 0001 BLDG SECONDS RES COMM: Need engineers inspection letter for wind bracing. Clean up RES COMM: trash on lot. Missing hanger on front LVL. Shower pan not RES COMM: ready. Insulate shower line 2nd floor. Tub drain above back RES COMM: door looks cracked and wet.	3/30/21 APPROVED WITH EXCEPT 3/30/21 DISAPPROVED	MP MP
21 00000910	6500 BOLD RULER LN 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Water test low. Missing cutoff valve outside of forms RES COMM: within 18". Clean up trash on lots. No barrier up around RES COMM: tap.	3/30/21 DISAPPROVED	MP
21 00000914	6508 BOLD RULER LN 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Missing cutoff valve outside of forms within 18" RES COMM: Clean up trash on lots. No barrier up around tap.	3/30/21 DISAPPROVED	MP
21 00000918	6504 BOLD RULER LN 10 00 BLDG, SF-NEW	1000 0001 BLDG ROUGH PLUMBING/GAS T RES COMM: Water test low. Missing cutoff valve outside of forms RES COMM: within 18". Clean up trash on lots. No barrier up around	3/30/21 DISAPPROVED	MP

RES COMM: tap.

21 00000920	9225 ARMADILLO TR 10 00 BLDG, SF-NEW	1005 0002 BLDG EXTERIOR SHEATHING RES COMM: Engineers inspection letter must show 2018 compliant	3/30/21 APPROVED WITH EXCEPT	MP
	10 00 BLDG, SF-NEW	1015 0001 BLDG SECONDS RES COMM: Need engineers letter for wind bracing. Missing window on RES COMM: back porch. Remove form board by elec.service. Gas gauge RES COMM: stuck. Missing anchors on interior braced walls. Nail plate RES COMM: plbg 1" and at WH. Backfall 2" revent at master. Clean up RES COMM: trash on lot and repair trash bin	3/30/21 DISAPPROVED	MP
21 00000931	6001 PARKER BLVD 32C 00 PLBG, COMMERCIAL IRRIGATION	3005 0009 PLBG PLUMBING ROUGH RES COMM: island south of building #2.	3/30/21 APPROVED	DJH
21 00000993	7904 TURNER DR 37 00 POOL, BELOW/INGROUND	6080 0001 POOL PRE-PLASTER	3/30/21 APPROVED	TC
	37 00 POOL, BELOW/INGROUND	0000 0001 MISC INSPECTOR'S CHOICE	3/30/21 APPROVED	TC
21 00001095	6113 PARKER BLVD 40T 00 CONSTRUCTION/SALES TRAILER	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: Place address on the trailer.	3/30/21 APPROVED WITH EXCEPT	DJH
21 00001136	8312 SAYERS LN 11 00 BLDG, SF/MINOR REMODEL 50SF+	0000 0001 MISC INSPECTOR'S CHOICE RES COMM: GAS LINE FOR POOL.	3/30/21 APPROVED	TC
21 00001233	6809 CRANE RD 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: Chair stell and cable as needed. Ufer ground must be in the RES COMM: bottom 2" of the beam. Plbg in beams must be sleeved. RES COMM: Provide washout pit.	3/30/21 APPROVED WITH EXCEPT	DJH
21 00001253	6813 CRANE RD 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE RES COMM: Sleeve plbg in the beams. Chair steel and cables as needed. RES COMM: Ufer ground must be within bottom 2" of the beam. Provide RES COMM: washout pit.	3/30/21 APPROVED WITH EXCEPT	DJH
21 00001260	8704 WOODBURY CT 10 00 BLDG, SF-NEW	1001 0001 BLDG STRUCTURAL CONCRETE	3/30/21 PARTIALLY APPROVED	TC
21 00001275	6208 ABBOTT AVE 42A 00 DECK/PATIO W/ COVER	1010 0002 BLDG FRAMING	3/30/21 APPROVED	TC
21 00001407	7348 HIDDEN OAKS DR 11 00 BLDG, SF/MINOR REMODEL 50SF+	1090 0001 BLDG FINAL-BUILDING DEPT RES COMM: ELECTRICAL NOT TRIMED OUT.	3/30/21 DISAPPROVED	TC
21 00001719	7505 NORTHFIELD DR 11 00 BLDG, SF/MINOR REMODEL 50SF+	1090 0001 BLDG FINAL-BUILDING DEPT	3/30/21 APPROVED	TC
21 00001760	7005 MEADOW PARK N 14 00 BLDG, SF FOUNDATION	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	3/30/21 APPROVED	TC
21 00001761	4129 FLORY ST 14 00 BLDG, SF FOUNDATION	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS.	3/30/21 APPROVED	TC
21 00001971	7232 SMITH FARM DR 10 00 BLDG, SF-NEW	1003 0001 BLDG TEMPORARY POLE	3/30/21 APPROVED	TC
21 00002069	6605 SABLE DR 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0003 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection	3/30/21 APPROVED	TC
21 00002241	6719 MID CITIES BLVD 13 00 BLDG, COMMERCIAL RMDL/REPR	1014 0001 BLDG ELEC ROUGH-BURY/WALL	3/30/21 APPROVED	DJH
21 00002267	6600 PARKVIEW DR 01R 00 C OF O - SINGLE FAMILY RENTAL	1094 0001 BLDG FINAL S.F. RENTAL UN REQ COMM: Single Family Rental Unit Inspection RES COMM: HOUSE MUST BE MOVE-IN READY BEFORE RENTAL INSPECTION. RES COMM: RECALL WHEN COMPLETED.	3/30/21 DISAPPROVED	TC
21 00002335	5513 FINIAN LN 18R 00 BLDG, RES RE-ROOF WITH DECKING	1037 0001 BLDG AS SPECIFIED BY BO REQ COMM: THIS INSPECTION WILL BE LISTED FOR UNUSUAL CIRCUMSTANCES. REQ COMM: THE SPECIFIC INSPECTION CRITERIA WILL BE SET OUT AT THE REQ COMM: TIME OF PERMIT ISSUANCE & WILL BE LISTED IN THE COMMENTS. RES COMM: NO ENTRY	3/30/21 DISAPPROVED	TC

21 00002371	8320 WESTWIND LN 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	3/30/21 APPROVED	GT
21 00002486	6801 SWITCHBACK TR 32R 00 PLBG, RESIDENTIAL IRRIGATION	3005 0001 PLBG PLUMBING ROUGH	3/30/21 APPROVED	MP
21 00002520	7041 BOULEVARD 26 01C 00 C OF O-NEW OCCUPANT/NEW USE	1095 0002 BLDG CERTIFICATE OF OCCY	3/30/21 APPROVED	DJH
21 00002592	6745 CYLINDA SUE CIR 24 00 ELEC, SERVICE CHANGE/ADD	2090 0002 ELEC FINAL	3/30/21 APPROVED	TC
21 00002607	7901 MID CITIES BLVD 212 23 00 ELEC, TEMPORARY SERVICE	2030 0001 ELEC TEMP ELEC/CLEAN & SH RES COMM: No access, door locked.	3/30/21 DISAPPROVED	DJH
21 00002635	3744 HOLLAND ST 35 00 PLBG, MISCELLANEOUS 35 00 PLBG, MISCELLANEOUS	3005 0001 PLBG PLUMBING ROUGH 3090 0001 PLBG PLUMBING FINAL	3/30/21 APPROVED 3/30/21 APPROVED	TC TC
21 00002644	7113 TRINIDAD DR 35 00 PLBG, MISCELLANEOUS	3090 0001 PLBG PLUMBING FINAL	3/30/21 APPROVED	TC
21 00002648	6824 RIDGETOP RD 35 00 PLBG, MISCELLANEOUS 35 00 PLBG, MISCELLANEOUS	3005 0001 PLBG PLUMBING ROUGH 3090 0001 PLBG PLUMBING FINAL	3/30/21 APPROVED 3/30/21 APPROVED	TC TC